

FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2017/ W2/931

Dated 28/06/2017

FIRE SAFETY CERTIFICATE

Certified that the **Aggarwal Millenium Tower** located at **Plot no. E – 1, 2, 3, Netaji Subhash Place, Pitampura, Delhi – 110034** comprised of 2 Blocks (LG+G+10 Upper Floors & LG+G+5 Upper Floors) was issued FSC vide Letter No. F6/DFS/MS/2014/341 dated 11-03-2014 The premises was re inspected by the officers concerned of this department on 24-05-2017 in the presence of Mr. Sunil Jain (Vice President) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Mercantile & Business Building” Group F & Group E with effect from 28/6/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 28/6/17 at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to: Sh. Sunil Jain (Vice President) Plot No. –1, 2, 3, Netaji Subhash Place, Pitampura, Delhi– 34.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Aggarwal Millenium Tower, E – 1, 2, 3, Netaji Subhash Place, Pitam Pura, Delhi – 110034.
2. Type of Occupancy : Mercantile + Business (Mixed), 2 Blocks (LG+G+10 Upper Floor & LG+G+5 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2014/341 dated 11-03-2014
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2000/1177 dated 06-07-2000
6. Date of inspection : 24-05-2017
7. Name of the Inspecting Officer : DO/west & ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Sunil Jain (Vice President)
9. Year of Construction : 2003
10. Applicant's letter No. : BPL/DIR/AMT/DFS/2K17/0211 dated 02-05-2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	60 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 provided	MR
	• Basements	2	2 provided	MR
	b. Width of staircases			
	• Upper floors	1.5m & 1m	Provided(Old case)	MR
	• Basements	1.5m & 1m	Provided(Old case)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Not Required	Open able window	NR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5m	Provided(Old Case)	MR
	f. Door Size	01m	Provided(Old Case)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Not Required	NR	NR
	• Fire Dampers	Not Required	NR	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NR	NR
	• Upper floors	12 a/c per hour	Provided open able window	MR
5.	Fire Extinguishers			


6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Not Required	NR	NR
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		1	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required	Provided	MR
		Required	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2850 lpm	Provided	MR
		75 m	Provided	MR
		2	Provided	MR
		220 lpm	Provided	MR
		75 m	Provided	MR
		2850 lpm	Provided	MR
		75 m	Provided	MR
		Required	Provided & Functional	MR
		Required	Provided	MR
		Not Required	NR	NR
		Not Required	NR	NR
		Not Required	NR	NR
		Not Required	NR	NR
14.		Captive water Storage for fire fighting		
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	2,00,000 litres	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		30, 000 litres	Provided	MR
		Required	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch 	Not Required	NR	NR
		Not Required	NR	NR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR


7.	Automatic fire detection and alarm	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	Not Required	NR	NR
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	2850 lpm	Provided	MR
	<ul style="list-style-type: none"> Discharge of main pump 	75 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of main pump 	2	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	220 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	75 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	2850 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	75 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	Required	Provided & Functional	MR
	<ul style="list-style-type: none"> ➤ Auto Staring/Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 			
	<ul style="list-style-type: none"> Terrace level 	Not Required	NR	NR
	<ul style="list-style-type: none"> ➤ Discharge of pump 	Not Required	NR	NR
	<ul style="list-style-type: none"> ➤ Head of the pump 	Not Required	NR	NR
	<ul style="list-style-type: none"> ➤ Power supply 	Not Required	NR	NR
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	Not Required	NR	NR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	2,00,000 litres	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw of connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	30, 000 litres	Provided	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	Not Required	NR	NR
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	Not Required	NR	NR
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Lift Signage 	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area 	Old Case	Old Case	MR
	<ul style="list-style-type: none"> ➤ Location 	5 th , 7 th & 9 th Floor	Provided	MR

19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/2014/341 dated 11-03-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



 Signature of the Inspecting Officer
 Name Udavir Singh
 Designation ADO/WP



 Signature of the Inspecting Officer
 Name Sh Mukesh Verma
 Designation DO/West

Dyefo. on leave


 22/06/17

DO/W Shuker also sign it



 22/06/17

CFO (West) 
 27/06/17