

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/2017/ W2/928

Dated: 28/6 /2017

**FIRE SAFETY CERTIFICATE**

Certified that the **Aggarwal Metro Heights** located at **Plot no. E – 5, Netaji Subhash Place, Pitampura, Delhi – 110034** comprised of Basement + Ground + 15 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2014/WZ/358 dated 14-03-2014. The premises was re inspected by the officers concerned of this department on 24-05-2017 in the presence of Mr. Sunil Jain (Vice President) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Mercantile & Business Building” Group F & Group E with effect from 28/6/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...28/6/17.... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

Copy to: Sh. Sunil Jain (Vice President) Plot No. E – 5, Netaji Subhash Place, Pitampura, Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1. Name & address of the building: Aggarwal Metro Heights, E – 5, Netaji Subhash Place, Pitam Pura, Delhi – 110034.
2. Type of Occupancy : Mercantile + Business (Mixed), Basement + Ground + 15 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2014/WZ/358 dated 14-03-14
5. Fire Safety directives Letter No. :No. F6/DFS/MS/BP/2006/400 dated 15-02-2006
6. Date of inspection : 24-05-2017
7. Name of the Inspecting Officer : DO (West) & ADO (WP)
8. Name and designation of Officer  
from the building side : Sh. Sunil Jain (Vice President)
9. Year of Construction : 2008
10. Applicant's letter No. : BPL/DIR/AMT/DFS/2K17/0067 dated 03-02-2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	2	2 Provided	MR
	b. Width of staircases			
	• Upper floors	1.25m & 1.5m	Provided (Old case)	MR
	• Basements	1.25m & 1.5m	Provided (Old case)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Open able window	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	Required	Provided(Old case)	MR
	f. Door Size	1m	Provided(Old case)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Found sealed	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Not Required	NR	NR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 a/c per hour	Exhaust fans found provided	MR
	• Upper floors	12 a/c per hour	Open able window	MR
5.	Fire Extinguishers			
	• Total numbers	55 nos.	Provided	MR
	• Types	CO2 & WCO2	Provided	MR
	• IS marking	IS	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	6.5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2850 lpm	Found Functional	MR
	➤ Head of main pump	110 m	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	110 m	Provided	MR
	➤ Standby Pump out put	2850 lpm	Provided	MR
	➤ Standby Pump Head	110 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided & Functional	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	Not Required	NR	NR
	➤ Head of the pump	Not Required	NR	NR
	➤ Power supply	Not Required	NR	NR
	➤ Auto starting of pump	Not Required	NR	NR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	2,00,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20, 000 litres	Provided	MR
15	Exit Signage	Required	More Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Found provided	MR
	➤ Pressurization of lift lobby	Required	Found Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	Required	Provided	MR

11-24

19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 flooding system for LT & HT panels	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/2014/WZ/358 dated 14-03-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~  
 Name Uday Vir Singh  
 Designation ADO/WP

*Sh Mukesh Verma*  
 Signature of the Inspecting Officer  
 Name Sh Mukesh Verma  
 Designation DO/west

Dy Cfo - on leave

CFO  
*Signature*  
 27/06/14 FT DS