

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/SCHOOL/WZ/2017/ 924

Dated: 23/06/2017

**FIRE SAFETY CERTIFICATE**

Certified that the AadharShila Vidyapeeth Located at CD Block Pitampura Delhi – 110034 comprised of Three Blocks (Two Block- B+G+3UF & One Block G+2UF) Floors was issued FSC vide Letter No. F6/MS/DFS/School/2013/WZ/686 Dated 08-08-2013 The premises was re inspected by the officer concerned of this department on 31-05-2017 in the presence of Mr. Byomakesh Mishra (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance circular Dated-17/01/2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 23/06/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .... 23/06/17 .... at New Delhi by.

  
(Atul Garg)

Chief Fire Officer  
Delhi Fire Service

Copy to:

The Principal, AadharShila Vidyapeeth CD Block Pitampura Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building by law 1983 and basement of Block 01 shall not be used for any purpose.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1. Name & address of the building: **AadharShila Vidyapeeth Located at CD Block Pitampura Delhi - 110034.**
2. Type of Occupancy : **Educational 03 Blocks (BL-1 & 3=B+G+3 Upper Floor)&(BL-2=G+2UF)**
3. Type of Case : **Renewal (Earlier FSC was issued to BL-3 only)**
4. Details of previous NO : **F6/MS/DFS/School/2013/WZ/686 Dated 08-08-2013(Earlier FSC was issued to BL-3 only)**
5. Fire Safety directives Letter No. : **circular Dated-17/01/2005**
6. Date of inspection : **31-05-2017**
7. Name of the Inspecting Officer : **Udaivir Singh,ADO (WP)**
8. Name and designation of Officer  
from the building side : **Mr. Byomakesh Misshra(Principal)**
9. Year of Construction : **2004**
10. Applicant's letter No. : **Nil Dated -11/05/2017**

No. of Students=2300
No. of class rooms=55
Plot area=8933m <sup>2</sup>
Covered area=2976m <sup>2</sup>

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No. dated-17-01-05/inspection note dated 5/07/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	05 mtr	MR(old case)
	• Gate width	5.0 mtr	3mtr	MR(old case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	BL-1=01 BL-2=01 BL-3=2	BL-1=02 BL-2=01 BL-3=03	MR
	• Basements	BL-1=2,BL-3=2	BL-1=1, BL-3=4	MR
	b. Width of staircases			
	• Upper floors	1.5mtrs each	1 <sup>st</sup> Bl=1x1.25m&1x1.4m 2 <sup>nd</sup> Bl=1x1.55m 3 <sup>rd</sup> Bl=1x1.62m,1x1.22m &1x1.4m	MR
	• Basements	BL-1=1x1.5m &1x1m BL-3=1x1.5m &1x1m	1 <sup>st</sup> BL=1x1.25m 3 <sup>rd</sup> BL=2x1.4m,1x1.8m & 1x1.24m	MR (Basement of BL-01 sealed)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	BL1&2=1 BL-3=2	Provided	MR
	e. Width Of Corridor	1.5 mtr	228 cm	MR
	f. Door Size	1.0 mtr	110 cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA



	<ul style="list-style-type: none"> <li>Basements</li> </ul>	30	Provided	MR(Exhaust fan provided)
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	10 nos.	65 Provided	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC & CO <sub>2</sub>	Provided	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	BL-1&2=1 each BL-3=2	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke (Audi)	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	GF	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	GF/All Floor	Provided	MR
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	Required(Audi)	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required (Audi)	Provided	MR
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	BL-3=2 BL-1 &2=1 each	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	BL-3=2 BL-1 &2=1 each	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	Provided	MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Staring/Manual stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	900 lpm & 180 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>			

22



14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	100kl	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	20,000 ltr	Provided	MR
	• Overhead Tank capacity			
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. **F6/MS/DFS/School/2013/WZ/686 Dated 08-08-2013** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

**Note;- Basement of Block 01 has been closed by brick wall and shall not be used for any purpose.**

Signature of the Inspecting Officer

Name Udai Vir Singh  
Designation ADO ( WP)

Signature of the Inspecting Officer

Name  
Designation

*DO/ West / 5/6/17*