


FORM 'H' :
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2017/WZ/958 Dated: 06/07/2017

FIRE SAFETY CERTIFICATE

Certified that the **Banquet Hall** at 16, Shivaji Marg, Main Najafgarh Road Industrial Area, New Delhi-110015 comprised of ground and one upper floor (and terrace floor room for kitchen) owned/occupied by **M/s S & S Hospitality Services**. was issued NOC/FSC vide this office letter No. **F6/MS/DFS/2014/WZ/462 dated 09/04/2014**. The premises was re-inspected by the officers concerned of this department on **20/04/2014** in the presence of **Sh. Sameer Arora (Owner)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service Rule 2010 and the building/premises is fit for **Class-D Assembly** occupancy with effect from...06/07/17.....for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Issued on...06/07/17.....at New Delhi by


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Sh. Sameer Arora
16, Shivaji Marg, Main Najafgarh Road Industrial Area, New Delhi-110015

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. All the doors, Exits and internal roads must be kept free from any obstruction.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : **M/s S & S Hospitality Services Inc.** at 16, Shivaji Marg, Main Najafgarh Road Indl. Area, New Delhi-110015
2. Type of Occupancy : Banquet Hall/Assembly (**Ground+one upper floor**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2014/WZ/462 dated 09/04/2014
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 20.04.2017
7. Name of the Inspecting Officers : Mukesh Verma DO (West)
8. Name and designation of officers
From the building side : Mr. Sameer Arora
9. Year of Construction :
10. Applicant's letter No. : nil dated 20-03-2017

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09 mtr	12 mtr	M.R.
	• Gate width	4.5 mtr	On main road	M.R.
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	Provided	M.R.
	• Basement	N.A.	N.A.	N.A.
	b. Width of staircases			
	• Upper Floors	2 mtr	Provided	M.R.
	• Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	2	2	M.R.
	e. Width of Corridor	Halls only	Halls only	M.R.
	f. Door size	2 mtr	2 X 210 cm 1 X 157 cm	M.R.
3.	Compartmentation.			
	• Fire check door	required	Provided	M.R.
	• Sealing of electrical shafts	N.A.	N.A.	N.A.



	<ul style="list-style-type: none"> • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.R.	N.R.	N.R.
		N.R.	N.R.	N.R.
		N.R.	N.R.	N.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N.A.	N.A.	N.A.
		Required	Provided	M.R.
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	15	16	M.R.
		Water CO ₂ & CO ₂ Required	Provided	M.R.
		ISI marks required	provided	M.R.
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2	Provided	M.R.
		30 m required	Provided	M.R.
		5 mm required	Provided	M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 	N.R.	Provided	M.R.
		G.F	Provided	M.R.
		G.F.	Provided	M.R.
		Required	Provided	M.R.
		Required all over	Provided	M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	Not Required	Provided	M.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N.A.	N.A.	N.A.
		N.R.	Provided	M.R.
		Required	Provided	M.R.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	150 mm	Provided	M.R.
		2	Provided	M.R.
		2	Provided	M.R.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N.R.	N.R.	N.R.
		N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.

②

	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	Terrace level			
	➤ Discharge of pump	900 LPM & 180 LPM (jockey)	Provided	M.R
	➤ Head of the pump	25 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	➤ Overhead Tank Capacity	15,000 ltrs	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.

20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.
-----	--	------	------	------

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standard of fire prevention and fire safety measure as required under the rules the NOC issued vide letter no. F6/MS/DFS/2014/WZ/462 dated 09/04/2014 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Signature of the Inspection Officer

Name Mukesh Verma

Designation D.O. (West)

Dy. (DOWZ) - on day off
CFO (West)
4/2/17
FTPL