

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No.F.6/DFS/MS/SCHOOL/2017/ 52/941

Dated: 30 / 06 / 2017

FIRE SAFETY CERTIFICATE

Certified that the Ganga International School located at Sawda, Ghevera-Nizampur Road, New Delhi-110081 comprised of Ground + One Upper Floors owned / occupied by Ganga International School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/2010/2537 dated 31/8/2010. The premises was re-inspected by the officer concerned of Fire Service on 13.06.2017 in the presence of Mr. Vipul Agarwal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Director of Education circular No. 262-362 dated 17/01/2005 and that the building / premises is fit for occupancy class-B (Educational) with effect from 30/06 /2017 for a period of three years subject to conditions printed below.

Issued on 30 / 06 / 17 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER

Copy to :-

1. The Principal, Ganga International School, Sawda, Ghevera-Nizampur Road, New Delhi-110081.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Ganga International School, Sawda, Ghevera-Nizampur Road, New Delhi-110081.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (G.F. & 1st Floor)
4. Details of previous NOC : F6/DFS/MS/2010/2537 dated 31/8/2010
5. Fire Safety directives Letter No.: DOE Cir. 262-362 dated 17/01/2005
6. Date of inspection : 13/06/2017
7. Name of the Inspecting Officer : A. K.-Jaiswal
8. Name and designation of Officer
from the building side : Mr. Vipul Agarwal
9. Year of Construction : 2006-2010
10. Applicant's letter No. : Nil dated 12/05/2017

Plot Area – 4 Acre Cov. Area – 4000 m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. Dated 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr	2.00 mtr X 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.50 mtr	1.90 mtr	MR
	f. Door Size	1 mtr	1 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	14	15	MR
	• Types	ISI marked DCP/CO ₂ /WCO ₂	Provided	MR
	• IS marking	Required	Provided	MR

6.	First - Aid Hose Reels	2	2	MR
	• Total numbers on each floor			
	• Length of hose reel hose	30Mtr.	30Mtr.	MR
	• Nozzle diameter	5mm.	5mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power supply	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	220 LPM (as per DOE Cir. Dt. 17/01/2005)	220 LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank	2,500 ltr(as per	2,500 ltr	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	NA	NA	NA
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A


Note:-General requirements for schools as per Director of Education circular dated 17/01/2005.

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set :- NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2010/2537 dated 31/8/2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O. (C) on leave
~~Dy. C.O. 7~~
~~cto in-charge~~
 22/06/17
 HT DLS
 F.T. is put up for sign. please


 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : A.D.O. (JwalaPuri)