

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/2017/Audi/956

Dated: 4/7/17

FIRE SAFETY CERTIFICATE

Certified that **M/s Sirifort Auditorium Complex (Auditorium I,II, III & IV)** located at **August Kranti Marg, New Delhi-110049**, comprised of basement, ground and first floor only, owned/occupied by **Directorate of Film Festivals** was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/2014/SZ/555**, dated **02.05.2014**. The premises was re-inspected by the officer concerned of this department on 19.06.2017 in the presence of Sh. Omparkash, Engineer and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for **Occupancy Class-D Assembly Building(Auditorium)** with effect from **4/7/2017** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **4/7/2017** at New Delhi by


(Vipin Kental)

Chief Fire Officer

T.No.011-23412225



Copy To:- 1. Joint C.P.Licensing, PS Defence Colony, New Delhi.
2. Sh. Tanu Rai, Dy. Director, Sirifort Auditorium Complex located at August Kranti Marg, New Delhi-110049.

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	15m	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	08nos	08nos	MR
	2. Basements	06nos.	06nos.	MR
	b. Width of staircase			
	1. Upper floors	Required	1.5m(each)	MR(old case)
	2. basements	Required	1.5m(each)	MR(old case)
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	02nos.	02nos.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	Audi-I=7at GF & 8 at balcony level, Audi-II=4at GF, Audi-III=2at GF & 2 at balcony level, Audi-IV=2at GF level (Each exit door is 1.35m wide)	MR(old case)
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 a/c per hour	Exhaust Fans Provided	MR
	Upper floors	12 a/c per hour	Exhaust Fans Provided	MR
5	Fire Extinguishers			
	Total numbers	200Nos	200 Nos. Provided	MR
	Types	ABC, CO2 & WCO2	ABC, W CO2 & CO2 ,	MR
	ISI marking	ISI	Provided	MR

INSPECTION REPORT

6	First-Aid Hose Reels.			
	Total numbers on each floor	02nos at basement floor, 09nos at ground floor & 04nos at 1st floor	02nos at basement floor, 09nos at ground floor & 04nos at 1st floor	MR
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Smoke, Heat & Beam	Smoke, Heat & Beam	MR
	Location of Main Panel	Ground Floor	Ground Floor	MR
	Location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup Provided	MR
	Hooter's location	All Areas	All Areas	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper floors	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	Size of riser/down-corner	150mm	150mm	MR
	Number of Hydrants per floor	02nos at basement floor, 09nos at ground floor & 04nos at 1st floor	02nos at basement floor, 09nos at ground floor & 04nos at 1st floor	MR
	hose Box	do-----	do-----	MR
12	Yard Hydrants.			
	total number of hydrants	10nos	10nos	MR
	house box	10nos	10nos	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2280LPM	2280LPM	MR
	b. Head of main pump	55m(each)	55m(each)	MR
	c. Number of main pumps	02nos	02nos	MR
	d. jockey pump out put	225LPM	225LPM(02nos)	MR
	e. jockey pump head	55m	55m(each)	MR
	f. Standby Pump output	2280LPM(Electrical)	2280LPM(Electrical)	MR
	g. Stanby Pump head	55m	55m	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	100,000 ltr	100,000 Ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	20000 ltr	20000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR

INSPECTION REPORT

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 flooding system Provided provided for electric sub-station and transformer rooms. MR			

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/2014/SZ/555, dated 02.05.14 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended. Also shortcomings communicated vide letter dated 12.05.17 have been complied at serial numbers 2,8,13,14 & 15. Reply letter on same lines is put up for kind consideration please.

[Handwritten Signature]
20/6/17

Signature of the Inspecting Officer
Name: Vedpal
Designation: ADO(SJ)

D.O. (SD)

[Handwritten Signature]
22/6/17

982/CR052
28/6-

[Handwritten Signature]
22/6/17

[Handwritten Signature]
22/6

CR0(72)

M.S cell

FTM,

[Handwritten mark]

