

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**



NO. F6/DFS/MS/School/2017/SZ/ 1008

Dated: 11/7/17

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Girls Sr. Sec. School, No.3, Palam Enclave, New Delhi-110045, having two blocks comprised of ground floor & ground plus one upper floor each was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2014/SZ/574 dated 18.6.2014. The said School building was re-inspected by the officer concerned of this department on 23.6.2017 in presence of Sh. Tara Chand (Estate Manager) & Sh. B L Meena (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance Directorate of Education circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 1.3.2011 and that the premises/building is fit for occupancy class B "Educational building" for two blocks comprised of ground plus one upper floor each with effect from...11/7/17... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on .....11/7/17..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  


Copy to:-

1. The Deputy Director (Education), Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. The Principal, Govt. Girls Sr. Sec. School, No.3, Palam Enclave, New Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



1	Name & address of the building	Govt Girls Senior Secondary School NO.3, Palam Enclave, New Delhi-110045.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal <b>Ground floor &amp; G + 1 Two Blocks/ Addition of Floor</b>	
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/748 Dated 18.06.2014	
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.	
6	Date of inspection	23.06 .2017	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh.Tarachand (Estate Manager) & Sh.B.L Meena (Principal)	
9	Year of construction	1984, 2016	
10	Applicant's letter No.	GGSSS/NO.3/PE/107 Dated 29.5 17	Management has constructed one more upper floor at Groud floor block, Now Both Blocks are G+1 upper floor

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	5 Mtrs.	Provided	M/R
	3) Width of internal road	N/A	N/A.	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos. each Block	2 Nos. each block	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.50 Mtrs. if less than 1.50 Mtrs. additional staircase of .75 Mtr.is required	<b>Block No.1:</b> 1.52 & 1.14 Mtrs. <b>New Block:</b> 1.50 Mtrs. each	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	e. Width of corridor	N/A	1.5 Mtrs.	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
	upper floors		Natural Vent.	MR
5	<b>Fire Extinguishers</b>			
	total numbers	One for 300 Sq.	15 Nos.	MR



6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	Provided	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A



M/9

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room	N/A	N/A	N/A
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:			ABC

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view compliance of the minimum standards on fire prevention and fire safety requirements under the rules, FSC issued vide letter No. F6/DFS/MS/2011/School/SZ/748 dated 18.6.2014 for two blocks having Ground floor & Ground plus one upper floor is recommended for Ground plus one upper floor for both blocks.

Accordingly DFA is put up for approval and signature please.

*S.P. Bhardwaj*  
S.P. Bhardwaj  
ADO (Dwarka)

472/00860  
27/6/2012

~~D/SW~~

*[Signature]*  
27/6/12

DLFO (S2)

*[Signature]*  
20/6

Chol (S2)

m. scell

FT 10.

*[Signature]*  
3/7



998/CP-82  
6/7/10/2.  
11/7/12