


No. F.6/DFS/MS/GH/2017/SZ/986

Dated: 10/07/2017

FIRE SAFETY CERTIFICATE

Certified that M/s **Irish Park Leisures Pvt Ltd** located at **Plot No. A-1/23, Safdarjung Enclave, New Delhi**, comprised of Basement (Storage), Stilt (Parking & Reception), Ground floor (09 Rooms), 1st floor (09 Rooms), 2nd floor (09 Rooms), 3rd floor (09 Rooms) was granted Fire Safety Certificate in the name of M/s Aricia Sourcing (P) Ltd by this department vide letter No. F.6/DFS/MS/GH/2014/SZ/1148 dated 05/09/2014. The premises was re-inspected by the officer concerned of this department on 16/06/2017 in the presence of Mr. Jeetu Ram (Admin) of the guest house and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Residential & lodging**" Group-A" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/07/2017 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Joint C.P. (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. M/s Irish Park Leisures P Ltd, Plot No. A-1/23, Safdarjung Enclave, New Delhi-110029

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Irish Park Leisures Pvt Ltd, Plot No. A-1/23, GF, FF, SF & TF, Safdarjung Enclave, New Delhi.		
2	Type of Occupancy	Residential & Lodging, Group-A (Guest House)		
3	Building Comprised of	Basement, Stilt, Ground + Three upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/GH/2014/SZ/1148 Dated 05-09-2014		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	16.06.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Jeetu Ram (Admin)		
10	Year of construction	2009-10	Basement (storage), Stilt (parking & reception), Ground, First, Second & Third floor (09 room at each floor), Total 36 rooms	
11	Applicant letter No.	No. 823/Joint. C.P./Lic. (H) Dated 20-04-2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC (30/09/2011) requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	20 mtr.	MR
	• Gate width	Required	6 mtr	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	• Upper floors	Required	Two	MR
	• Basement floor	Required	Two	MR
	b. Width of Staircase			
	• Upper floors	Required	1.25 & 0.80 mtr	MR
	• Basement floor	Required	1.25 & 1.25 mtr	MR
	c. Protection of exits			
	• Fire check door	Required	Provided in basement	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 mtr	1 mtr (final exit)	MR
3	Compartmentation.			
	• Fire check door.	Required in basement	Required in basement	MR
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	30 ACPH	Provided exhaust fans	MR
	• Upper floors	12 ACPH	Provided exhaust fans	MR
5.	Fire Extinguishers.			
	• Total numbers		12 No's	MR
	• Types	ISI marked	ABC-06, W.Co2-06	MR
	• ISI Marking		Yes	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.		One	MR
	• Length of hose-reel hose.	Hose-reel	30 m	MR
	• Nozzle Diameter		05 mm	MR

7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Smoke	MR
	• Location of Main Panel	Required	Stilt floor	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	63 mm	N/A
	• Number of Hydrant per floor	N/A	1 No	N/A
	• Hose box.	N/A	1 No	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	Two	N/A
	• Hose box.	N/A	Two	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	15,000 Ltr.	15,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A


N/12

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	Provided one ABC type fire extinguisher near electrical panel	N/A

The Fire protection systems provided in the building were randomly checked/ tested and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/GH/2014/SZ/1148 dated 05-19-2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.



Signature of the Inspecting Officer
 Name : R.N. Singh
 Designation: ADO

Irish Park Leisures Pvt Ltd, Plot No.A-1/23, Safdarjung Enclave, New Delhi

DO (SD)

