

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI- 110001.

NO.F6/DFS/MS/School/2017/SZ/ 1007

Dated: 11/7/17

FIRE SAFETY CERTIFICATE

Certified that the Mother's Valley School located at Plot No.91, Goyla Khurd, New Delhi-110043, comprised of ground plus two upper floors was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2014/SZ/487 dated 16.4.2014. The said school building was re-inspected by the officer concerned of this department on 22.6.2017 in presence of Sh. Anil Kumar (Representative) and found that the Premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and that the building is fit for occupancy class B "Educational building" with effect from...11/7/17... for a period of **three years**, in accordance with rule 36 unless renewed 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service, Rules 2010, printed overleaf.

Issued on ...11/7/17... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Deputy Director (Education), SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi-110002.
2. Manager, Mother's Valley School located at Plot No.91, Goyla Khurd, New Delhi-110043.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Mother's Valley School, Plot No.91. Goyla Khurd, New Delhi-110043.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal (G+2 upper floors)	
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/487 dated 16.4.2014	
5	Fire safety directives letter No	DOE CIR. Dated 1.3.2011	
6	Date of inspection	22.6.2017	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Anil Kumar (Representative)	
9	Year of construction	2008	
10	Applicant's letter No.	Nil Dated 6.6.2017	(Ground plus two upper floors)

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ DOE CIR. Dated 1.3.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtr., if width less than 1.50 additional .75 Mtr. wide staircase is required	1.20 & .80 Mtr.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
		12 a/c per hour		
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
	total numbers	2 Nos. Each Floor (CO2 OR ABC) ISI	6 Nos	MR
	Types		ABC	MR
	ISI marking		Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA			N/A
9	Public Address System.			N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
d. Auto starting of pump	Required	Provided	MR	
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.			MR
	Required	Provided	MR	

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC fire extinguisher provided neat electric meter			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety requirements as DOE Cir. Dated 1.3.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2014/SZ/487 dated 16.4.2014 is recommended under rule 37 of the Delhi Fire Service Rules 2010 for ground plus two upper floors.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
 S.P. Bhardwaj
 ADO (Dwarka)

453/DO/SW
 23/06/2017

DO/SW
[Signature]
 23/6/2017

DCFO (S2)

[Signature]
 2017



997/CFOS
 6/7/17/17

CFOS
 m/seel

FTD
 6/7