

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2017/NDZ/ 981

Dated: 10/7/17

FIRE SAFETY CERTIFICATE

Certified that the Universal Nursery School at A- Block, Preet Vihar, Delhi-92, owned/occupied by Universal Nursery School, comprised of basement & ground floor was issued FSC vide letter No. F.6/DFS/MS/School/2014/NDZ/356 dated-25/03/14. The school building was inspected by the officer concerned of this department on 27/06/17 in the presence of **Smt. Maya Gupta (Principal)** of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the directives letter no. F.6/DFS/MS/BP/2004/1700 dated 03.08.2004 and the school building is fit for occupancy class "B" 'Educational Building' with effect from 10/7/17..... for a period of **three** years, subject to conditions, printed overleaf.

Issued on 10/7/17 at New Delhi by


(Vipin Kental)
Chief Fire Officer

To,

✓
The Principal,
Universal Nursery School,
A- Block, Preet Vihar, Delhi -92.

Extrac

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

- N III
1. Name & address of the building : Universal Nursery School at A- Block, Preet Vihar, Delhi -92.
 2. Building is comprised of : Basement & Ground floor only.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F6/DFS/MS/school/NDZ/2014 dated 25/03/14
 6. Fire Safety direction letter No : F.6/DFS/MS/BP/2004/1700 dated 03.08.2004
 7. Date of Inspection : 23/06/2017
 8. Name of the Inspecting officers : A DO R.K.Yadav
Name and designation of Officer
 9. from the building side : Smt.Maya Gupta (Principal)
 10. Year of Construction : 2006
 11. Applicant's letter No : dated 17/05/17

N O.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 Mtrs.	06 Mtrs.	MR
	• Gate width	4.5 Mtrs.	06 Mtrs..	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	02 Nos	02 Nos.	MR
	B. Width of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	1.5 M	1.5 M & .80 M	MR (old case)
	c. Protection of exits	Required	Provided	MR
	• Fire check door	N/A	N/A	N/A
	• Pressurization			
	e. No. of continuous staircases to terrace	1no.	1 No.	MR
	g. Width of Corridor	1.5 M	2.0 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Ventilated	MR
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	05 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	Provided	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 mm	5 mm	MR

N/12

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	Provided	MR
	• Number of hydrants per floor	1 No.	1 No.	MR
	• Hose Box	1No.	1 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	40 M	40 M	MR
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
15	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR

N/13

16	Exit Signage.	N/A	N/A	N/A
	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
17	• Lift Signage	N/A	N/A	N/A
18	Standby power supply	N/A	N/A	N/A
	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
19	• Location	N/A	N/A	N/A
	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
20	• Building Floor Plans	N/A	N/A	N/A
	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards of fire prevention and fire Safety measured as required under the rules. The fire safety certificate issued vide letter no. F.6/DFS/MS/2011/642 dated 11.04.2011, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav

Signature of the Inspecting Officer

Name:-R.K.Yadav

Designation:-ADO(LN)

Submitted please.

DO (ED)

*file
2/17*

Devo (DD2)

317