

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001.

No.F.6/DFS/MS/School/2017/NDZ/ 1090

Dated: 14/7/17

FIRE SAFETY CERTIFICATE

Certified that the Nursery School (Proposed) IP Extn., Mandawali, Fazalpur, Delhi, comprised of basement, stilt, ground plus two upper floors, owned/occupied by Maharaja Surajmal Education Society have complied with the fire prevention and fire safety requirements in accordance with the NBC Part-IV and verified by the officer concerned of this department on 28/06/17 in the presence of Mr. Gajender Singh (Care taker) of the school and found that the school building is fit for occupancy class 'B 'Educational Building' for with effect from ....14/7/17... for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on...14/7/17..... at New Delhi by

*Vipin Kental*  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

To,

The Principal,  
Nursery School, IP Extn., Mandawali, Fazilpur,  
Delhi- 110092.

Exdms

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
5. This Fire-Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

- N/S
- 1 Name & address of the building : Proposed Nursery School Building, IP Extn., Mandawali, Fazilpur, Delhi -110092.
  - 2 Building is comprised of :Basement,Stilt+Gr.+ 2upper floors.
  - 3 Type of Occupancy :Educational(Proposed)
  - 4 Type of Case :New
  - 5 Details of Previous FSC letter :NIL
  - 6 Fire Safety directives letter No :F6/DFS/MS/BP/2012/4392 Dated: 27/11/12
  - 7 Date of Inspection : 28/06/17
  - 8 Name of the Inspecting officers :DO S.K.Dua & ADO R.K. Yadav
  - 9 Name and designation of Officer from the building side :Mr.Gajender Singh (Care taker)
  - 10 Year of Construction : 2016
  - 11 Applicant's letter No : Nil dated


NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	31.80 Mtrs	MR ✓
	• Gate width	4.5 Mtrs	4.5 Mtrs	MR ✓
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 Nos.	2 Nos.	MR ✓
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 & 1.25 m	1.5 & 1.25 M	MR ✓
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
		2 nos.	2 nos.	MR ✓
	g. Width of Corridor	1.5 M	2.0 M	MR ✓
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR ✓
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	08 Nos.	08 Nos.	MR ✓
	• types	ABC & Co2	ABC & Co2	MR ✓
	• ISI marking	ISI marked	Provided	MR ✓


6	First-aid-Hose Reels.			
	Total numbers of each floor	1 No.	1 No.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR ✓
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR ✓
	➤ Head of the Pump	40 M	40 M	MR ✓
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 Ltrs.	15,000 Ltrs.	MR ✓
15	Exit Signage.			
		Required	Provided	MR ✓


16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

  
 Signature of the Inspecting Officer  
 Name : R.K. Yadav  
 Designation : ADO(LN)

  
 Signature of the Inspecting Officer  
 Name : S.K. Dua  
 Designation : DO(ED)

  
 DEFO (ND)