

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/2017/ **N021 969**

Dated : **7/7/17**

FIRE SAFETY CERTIFICATE

Certified that the Ambrosia Bliss Restaurant (A Unit of Felicia Entertainments Pvt. Ltd.) located at L-51 to 54, SF, Outer Circle, Connaught Place, New Delhi comprises of Ground + 02 Upper floor, Restaurant running at 2nd floor was granted FSC by this department vide letter No.F6/DFS/MS/EH/2014/NDZ/603 dated 15/05/14. The premises was re-inspected by the officer concerned of this department on 29/06/17 in the presence of Mr. Neeraj Kumar (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D** with effect from **7/7/17** for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued **7/7/17** at New Delhi by.

7/7/17
(Vipin Kental)
Chief Fire officer
Delhi Fire Service

Copy to:-

1. The Medical Officer of Health,
Health Department, Palika Kendra, New Delhi.
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
3. The Manager,
Ambrosia Bliss Restaurant (A Unit of Felicia Entertainments Pvt. Ltd.) at L-51 to 54,
SF, Outer Circle, Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building Ambrosia Bliss Restaurant (A Unit of Felicia Entertainments Pvt. Ltd.) at L-51 to 54, SF, Outer Circle, Connaught Place, New Delhi.
2. Type of occupancy:- Assembly Building Group-D
Gr. + 02 upper floors, Restaurant running at 2nd floor
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/2014/NDZ/603 dated 15/05/14
5. Fire safety directives No.- N/A
6. Date of inspection:- 29/06/17
7. Name of the inspecting officer:- Sh. Sunil Chawdhary Dy. CFO (NDZ) & Sh. Manoj Kumar Sharma (ADO/CC)
8. Name & designation of officer from the building side:- Mr. Neeraj Kumar (Manager)
9. Year of construction:- Old Heritage Bldg.
10. Applicant's letter No:- Nil diary dated 31/05/2017

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr	12 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mtr. Old Heritage Bldg.	1.0 & 1.25 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		01	02	MR
	E. Width of corridor			
		N/A	N/A	N/A
	F. Door size			
		2 mtr.	2 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	02	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM x 2	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR

- N/10 -

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/2014/NDZ/603 dated 15/05/14 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name :- Sh. Sunil Chawdhary
Designation :- DCFO (NDZ)

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- ADO (CC)

DO - MR
DCFO
M.K. Sharma