

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI- 110001**




NO.F6/DFS/MS/School/2017/SZ/ 1021

Dated: 13/7/19

**FIRE SAFETY CERTIFICATE**

Certified that the Delhi Height School located at Khasra No. 7/23, Qutab Vihar Phase-1, G Block, Village Kutubpur, New Delhi-110071, owned/occupied by Leelawati Education and charitable Trust (Regd.) comprised of ground plus two upper floors, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officers concerned of fire service on 13.6.2017 in presence of Sh. Akash Yadav (Managing Trustee) and that the building is fit for occupancy class B "Educational building" with effect from...13/7/17... for a period of **three** years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on ...13/7/19..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
  


Copy to:-

1. Dy. Director (Education) GNCT of Delhi, Old Secretariat, Delhi-110054.
2. Sh. Akash Yadav (Managing Trustee) Leelawati Education and charitable Trust (Regd.) House No.70, Village Bagdola, Sector-8, Dwarka, New Delhi-110077.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



## INSPECTION REPORT

1	Name & address of the building	Delhi Heights School (Leelawati Education and Cheritable Trust) Khasra No. 7/23, , Qutab Vihar Phase-1, G Block, Village- Kutabpur, New Delhi-110071.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New (Ground + Two Upper Floors)		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	NBC Requirements		
6	Date of inspection	13.6.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Akash Yadav (Managing Trustee)		
9	Year of construction	2016		
10	Applicant's letter No.	Nil dated 19.5.2017		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Direct Accessible From Road	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.50 & 1 Mtr.	1.60 Mtrs. & one of 1.38 to 1.50 Mtr. ( Area less than 500 Sq. M at floor)	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Two	Two	MR
	e. Width of corridor	1.50 Mtrs.	1.75 Mtrs.	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
		12 a/c per hour		



2/16

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	2 Nos. Each Floor	7 Nos.	MR
	Types	(Co2 OR ABC)	ABC	MR
	ISI marking	ISI Marked	ISI Marked	MR
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	One each floor	One each floor	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	30 m	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	40 Meter	40 Meters	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 Ltrs.	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR



M17

16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any:</b> ABC Fire extinguisher provided near electric panel			MR

Fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcoming vide letter no. F6/DFS/MS/School/SZ/2745 dated 24.11.2016 found rectified. ✓

Keeping in view compliance of the minimum standards on fire prevention and fire safety requirements under the rules/National Building Code, Fire Safety Certificate is recommended for ground plus two upper floors under rule 35 of the Delhi Fire Service Act 2007 & Rules 2010

Accordingly DFA is put up for approval and signature please.

*Sun*  
14/6/17  
S.P. Bhardwaj  
ADO (Dwarka)

42/20/5W  
15/06/2017

~~DOSW~~

*[Signature]*  
14/6/17

~~DFO (SR)~~

*[Signature]*  
15/6

955/CF 52  
19/6/17

CFD (SR)

Pl speak about 2 b(1)

