

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**


No.F6/DFS/MS/GH/2017/ NDZ 11059

Dated : 18/7/17

FIRE SAFETY CERTIFICATE

Certified that M/S **Goutam Hindu Hotel** located at **185, Church Mission Road, Fatehpuri, Delhi-110006**. comprised of Ground floor (commercial use other properties), 1st floor (Office + 07 guest rooms) & 2nd floor (08 guest rooms) Total 15 guest rooms was granted FSC by this department vide letter No.**F6/DFS/MS/GH/2014/NDZ/583** dated **08/05/2014**. The premise was re-inspected by the officer concerned of this department on **12/07/17** in the presence of Sh. Deepak Mehta, Owner of the guest house and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 for 15 guest rooms only as above** with effect from 18/7/17 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 18/7/17 at New Delhi by.


(Sunil Chowdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

- 1 The Addl.. C.P.(Lic.), Police Station, Defence colony, 1st floor, New Delhi.
2. The Owner, Goutam Hindu Hotel, 185 Church Mission Road, Fatehpuri, Delhi-110006.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed / unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to it expiry

N/25

INSPECTION REPORT

1. Name & address of the building:- M/S Goutam Hindu Hotel, 185 Church Mission Road, Fatehpuri, Delhi-110006.
2. Type of occupancy:- Residential Group A-1 (Ground+ 2 upper floors), GF- commercial use, 1st fl – Office + 07 guest rooms, 2nd fl - 08 guest rooms Total 15 guest rooms
3. Type of case:- Renewal
4. Details of previous FSC: - No. F6/DFS/MS/GH/2014/NDZ/583 dated 08/05/2014.
5. Fire safety directives No.- N/A
6. Date of inspection:- 12/07/17
7. Name of the inspecting officer:- A. D.O. Mehmood
8. Name & designation of officer
From the building side:- Sh. Deepak Mehta(owner)
9. Year of construction:- 1934
10. Applicant's letter No:- 1191/Addl. C.P./Lic(H), dated - 13/06/2017

Old case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement (Existing Fire Safety Measures)	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	80 to 120 cms.	80 to 120 cms.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No.	01 No.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	07 Nos.	MR




	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A


14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A


The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/GH/2014/NDZ/583 dated 08/05/2014, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended

D.O. (Central)


Mehmood
Assistant Divisional Officer


17/2/17


Dy CRO (NDZ)


17/2