

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

Fax: 011-23412593, Ph. 011-23414250

NO. F6/MS/DFS/ Mall/2017/WZ/ 976

DATED: 7/7/17

FIRE SAFETY CERTIFICATE

Certified that the Multiplex Garg Trade Centre, Plot No. 6, Sector-11, Delhi-110085 comprised of basement ground two upper floors plus projection room was granted NOC by this department vide letter no. F6/DFS/MS/2006/1122 dated 16.05.2006. The premises was re-inspected by the officers concerned of this department on 27.06.2017 in the presence of Sh. Padmender Singh (Mall Manager) and found that the mall deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building fit for occupancy Group " Mixed" with effect from 7/7/17..... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to condition as mentioned below.

Issued on 7/7/17 at New Delhi by


(Atul Garg)
Chief Fire Officer

Copy To:-

The Authorized Signatory, Shwet Garg Nirman Pvt. Ltd, Plot No. 6, Garg Trade Centre, Sector-11, Rohini, Delhi-110085

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | | | |
|---------------|--|---|---|-------------------------|
| 1 | Name & address of the building | Multiplex Garg Trade Centre, Plot No. 6, Sector-11, Delhi-110085. | | |
| 2 | Type of Occupancy | Mixed Occupancy | | |
| 3 | Building comprised of | Basement, ground ,2 upper floors plus projection room | | |
| 4 | Type of case | Renewal | | |
| 5 | Details of previous NOC | F6/DFS/MS/2006/1122 dated 16.05.2006 | | |
| 6 | Fire safety directives letter No | F6/DFS/MS/BP/2002/2329 dated 2.12.2002 | | |
| 7 | Date of inspection | 27.06.2017 | | |
| 8 | Name of the inspecting Officers | DCFO Dharampal Bhardwaj & ADO Rajesh Kumar | | |
| 9 | Name and designation of officers from the building side | Sh. Padmender Singh (Mall Manager) | | |
| 10 | Year of construction | 2006 | | |
| 11 | Applicant's letter No. | Nil dated 30.05.2017 | | |
| S. NO. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement/ Old Case | Provided at site | Remarks MR / NMR |
| 1 | Access to building | | | |
| | 1) Road width | 9 Mtr | Provided | MR |
| | 2) Gate width | 5 Mtr | Provided | MR |
| | 3) Width of internal road | 6 Mtr | Provided | MR |
| 2 | Number, width Type & arrangement of exits | | | |
| | a. Number of staircases | | | |
| | 1. Upper floors | 7 | 7 | MR |
| | 2. basements | 4 Stirs + 1 Ramps | 4+1 Provided | MR |
| | b. Width of staircase | | | |
| | 1. Upper floors | 1.5 Mtr & 2 Mtr | 1.62, 1.5, 1.65, 1.72, 1.57, 1.75 & 2 Mtr | MR |
| | 2. basements | 1.5 Mtr | 1.45, 1.63, 1.65 & 1.49 | MR |
| | c. Protection of exits | | | |
| | 1. Fire check door | Required | Provided | MR |
| | 2. Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircase to terrace | Required | 5 Nos. Provided | MR |
| | e. Width of corridor | 1.5 Mtr | Provided | MR |
| | f. Door size | 1.5 Mtr | Provided | MR |
| 3 | Compartmentation. | | | |
| | 1. Fire check door | Required | Provided | MR |
| | 2. Sealing of electrical shafts | Required | Provided | MR |
| | 3. Fire Rating of shaft door | N/A | N/A | N/A |
| | 4. water curtain | N/A | N/A | N/A |
| | 5. Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management system. | | | |
| | basement | 30 a/c per hour | Exhust Fans Provided | MR |
| | upper floors | 12 a/c per hour | Natural Ventilation | MR |
| 5 | Fire Extinguishers | | | |
| | total numbers | | 15 Provdied | MR |
| | Types | | ABC, CO2, Water Co2 | MR |
| | ISI marking | ISI | Provided | MR |
| 6 | First-Aid Hose Reels. | | | |
| | total numbers on each floor | Gr-2nos., 1st -2nos., 2nd - 7 nos. & Proj. Room- 1no. | Provided | MR |
| | Length of Hose reel hose | 30 Mtr | Provided | MR |
| | Nozzle Diameter | 5mm | Provided | MR |

| | | | | |
|----|--|--------------|----------|-----|
| | Type of detectors | N/A | N/A | N/A |
| | location of Main Panel | N/A | N/A | N/A |
| | location of Repeater panel | N/A | N/A | N/A |
| | Alternate source of power | N/A | N/A | N/A |
| | hooter's location | N/A | N/A | N/A |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | basement | Required | Provided | MR |
| | upper floors | Required | Provided | MR |
| | sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | Size of riser/down-corner | 150 MM | Provided | MR |
| | Number of Hydrants per floor | 2 Nos | Provided | MR |
| | hose Box | 2nos. | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | total number of hydrants | 5 Nos | Provided | MR |
| | house box | 5 Nos. | Provided | MR |
| 13 | Pumping arrangements | | | |
| | 1. Ground level | | | |
| | a. Discharge of main Pump | 2850 LPM | Provided | MR |
| | b. Head of main pump | 60 Mtr | Provided | MR |
| | c. Number of main pumps | One | Two | MR |
| | d. jockey pump out put | 180 LPM | Provided | MR |
| | e. jockey pump head | 60 Mtr | Provided | MR |
| | f. Standby Pump output | 2850 LPM | Provided | MR |
| | g. Stanby Pump head | 60 Mtr | Provided | MR |
| | h. Auto Starting/Manual stopping | Required | Provided | MR |
| | pump house access | Required | Provided | MR |
| | 2. Terrace level | | | |
| | a. Discharge of pump | N/A | N/A | N/A |
| | b. head of the pump | N/A | N/A | N/A |
| | c. Power supply | N/A | N/A | N/A |
| | d. Auto starting of pump | N/A | N/A | N/A |
| 14 | Captive water storage for fire fighting | | | |
| | 1. Underground tank capacity | 2,50,000 ltr | Provided | MR |
| | a. Draw-off connection | Required | Provided | MR |
| | b. fire service inlet | Required | Provided | MR |
| | c. Access to tank | Required | Provided | MR |
| | d. Over head tank Capacity | 30,000 Ltr | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of lifts. | | | |
| | a. Pressurization of lift shaft | N/A | N/A | N/A |
| | b. Pressurization of lift lobby | N/A | N/A | N/A |
| | c. Communication in lift car | Required | Provided | MR |
| | d. Fireman's grounding switch | Required | Provided | MR |
| | e. Lift signage | Required | Provided | MR |
| 17 | Standby power supply | Required | Provided | MR |

| | | | | |
|----|---|----------|---------------------------------|-----|
| 1 | Refuge Area. | | | |
| | total area | N/A | N/A | N/A |
| | location | N/A | N/A | N/A |
| 19 | Fire control room | | | |
| | a. Detector system Panel | N/A | N/A | N/A |
| | b. Flow switch Panel | N/A | N/A | N/A |
| | c. PA system Panel | Required | Provided | MR |
| | d. Batter backup | Required | Provided | MR |
| | e. Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special risks, if any: | Required | Co2 Fire Extinguishers Provided | MR |

The shortcoming issued vide letter no. F6/DFS/MS/2017/432 dated 02.06.2017 has been rectified.

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter No. F6/DFS/MS/2006/1122 dated 16.05.2006 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer: *[Signature]* 4/7/17

Signature of the inspecting of: *[Signature]* 3.7.17

Signature of the inspecting officer: *[Signature]* 27/6

Name: Dharampal Bhardwaj
Designation: DCFO (West Zone)

Name: Suresh Singh
Designation: DO (West Zone)

Name: Rajesh Kumar
Designation: ADO (RN)

CFD West
[Signature]
5/07/17
FIP

ADY RN

As approved; F.T. letter is put up for your signature pl.

CFD/w2
[Signature]
7/07/17

[Signature]
06/07/2017