

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2017/ *ND2*) *1026*

Dated *13/07/17*

FIRE SAFETY CERTIFICATE

Certified that **Extn. of Parliament House Annexe Block A & B, Parliament House Complex, New Delhi** comprised of **A - Block - 2 B + Ground + 2 upper Floors, B - Block, B + Ground + 6 upper Floors** owned /occupied by Parliament House has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 09-06-2017 in the presence of Mr. Katyal AE (E) that the building / premises, is fit for occupancy class Business Building with effect from ~~-----13/07/17~~-----2017 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on*13/07/17*..... at New Delhi by.

Vipin Kental
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Chief Architect,
Department of Architecture and Environs,
New Delhi Municipal Council, Palika Kendra, New Delhi.
2. The Executive Engineer (Elect.),
CPWD, Parliament House Annexe Project
Electric Division; 36 ,Gurudwara Rakab Ganj Road,New Delhi-110001.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation i case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N-13

INSPECTION REPORT

1. Name & address of the building:- Parliament House Annexe Block A & B,
Parliament House Complex, New Delhi.
2. Type of occupancy:- Business Building
A - Block - 2 B + Ground + 2 upper Floors
B - Block - B + Ground + 6 upper Floors
3. Type of case:- Fresh
4. Details of previous FSC:- N/A
5. Fire safety directives No.- F6/DFS/MS/BP/2009/212 dated
23/01/2009 & F6/DFS/MS/BP/2012/82
dated 10/01/2012
6. Date of inspection:- 09/06/17
7. Name of the inspecting officer:- Sh. Sunil Chawdhary DCFO/NDZ,
Sh. G.S.Chauhan DO/CD
8. Name & designation of officer
From the building side:- Mr. Katyal AE (E)
9. Year of construction:- 2010
10. Applicant's letter No:- No.54(3)/PHAPED/2017/199 Dated
18/05/17

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Required NBC - IV	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	35 mtr.	MR
	2) Gate width	4.5 mtr.	7.50 mtr.	MR
	3) Width of internal road	06 mtr.	06 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	07 Nos.	07 Nos.	MR
	2. Basements	10 Nos.	10 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	A- Block 04 Nos. 1.50 mtr each. B- Block 03 Nos. 1.50 mtr each	MR
	2. Basements	1.50 mtr.	A- Block 07 Nos. 1.50 mtr each. B- Block 03 Nos. 1.50 mtr each	MR
	C. Protection of exits			
	1. Fire check door	Required	provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	04	A- Block 04 Nos. B- Block 03 Nos.	MR
	E. Width of corridor	2 mtr.	2.3 mtr.	MR
	F. Door size	1.25 mtr.	1.25 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Provided	MR

5.	Fire Extinguishers			
	1) Total numbers	Required	Provided	MR
	2) Types	ABC, CO2 & W. CO2	ABC, CO2 & W. CO2	MR
	3) ISI marking	ISI	Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	11 No.	A- block 08 No. B- block 03 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Ground floor	Ground floor	MR
	3) Location of repeater panel	Security Room	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Every floor	Every floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	provided	MR
	2) Upper floors	N/A	provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm.	150 mm.	MR
	2) Number of hydrants per floor	11 Nos.	A-block-08 Nos., B-block-03 Nos.	MR
	3) Hose box at each floor	11 Nos.	11 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	06 Nos.	06 Nos.	MR
	2) Hose box	06 Nos.	06 Nos.	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	85 mtr.	85 mtr.	MR
	c) Number of main pump	2 Nos.	2 Nos.	MR
	d) Jockey pump output	180 LPM	200 LPM	MR
	e) Jockey pump head	85 mtr.	85 mtr.	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	90 mtr.	90 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting Existing			
	1) Under ground tank capacity	2,00,000 ltrs.	3,00,000 ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltrs.	20,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR


4-15

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	Required	provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	Required	Provided at 5 th floor of B Block	MR
19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer



Name :- Sh. Sunil Chwudhary
Designation :- DCFO (NDZ)

Signature of the Inspecting Officer



Name :- G.S Chauhan
Designation :- DO (CD)

367/CF/202
12/7/12/2

CF of

M. S. Chauhan

11/7

F.t. is put up for signature. please