

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F6/OFS/MS/2017/Cinema/W2/962

Dated 6/07/2017

FIRE SAFETY CERTIFICATE

Certified that the PVR Prashant Vihar (Audi. 1 to 3) Sector – 14, Rohini, Delhi – 110085 located at first floor in the building comprised of basement, ground and 04 upper floors owned / occupied by Aggarwal Entertainment Pvt. Ltd was issued fire safety certificate vide letter no. F6/MS/DFS/2006/1272 dated 07/06/2006 and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified by the officer concerned of Delhi Fire Service on 04.07.2017 in the presence of Sh. Dhurav, (Manager) and that the premises is fit for occupancy Group Class – D Assembly with effect from 6 / 7 / 2017 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

Issued on 6/07/17 at New Delhi by.


(Atul Garg)

Chief Fire Officer
Ph:- 011-23414250

Copy to:-

Authorized Signatory, PVR Prashant Vihar, Sec- 14, Rohini, Delhi – 110085.

INSPECTION REPORT

1. Name & address of the building : PVR Prashant Vihar Sec-14 Rohini. Delhi.
2. Type of Occupancy : Assembly (03 Audi)
3. Type of Case :Renewal
4. Details of previous NOC : F6/MS/DFS/2006/1272 Dated: 07/06/2006
5. Fire Safety directives letter No : F.6/MS/DFS/BP/2004/225 Dated : 28/01/2004
6. Date of inspection : 04.07.2017
7. Name of the Inspecting Officers : ADO/RN
8. Name and designation of officers
from the building side : Sh. Dhurav, Manager
9. Year of Construction :2004
10. Applicant's letter No. :Nil dated 06/06/2017

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Delhi Cinematograph Rules	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9m	18m	MR
	• Gate width	06 m	06m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	05+01	MR
	• Basements	B- I,02 + 01 ramp B- II, 02 + 01 ramp	03 + 01 ramp 04 + 01 ramp	MR MR
	b. Width of staircases			MR
	• Upper Floors	150 m each	1.50 m each + 01 ramp provided	MR
	• Basements	1.50m each + 2m ramp in B-I & II	1.50m each + 2m ramp in B-I & II	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.50 m	02.m	MR
	f. Door Size	1.5 m	1.5 m each	MR


3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	• Total numbers	25nos	27nos	MR
	• Types	WCO ₂ , DCP type	20 WCO ₂ , 07 DCP type	MR
	• IS marking	ISI marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	04 in each audi	04	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system. Common with mall			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	G.F	Provided	MR
	• Location of Repeater Panel	Each floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	At strategic locations	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR

11	Internal Hydrants			
	• Size of riser/down-comer	4"	Provided	MR
	• Number of hydrants per floor	One in each Audi	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	Required 06	Provided 06	MR
	• Hose Box	Required 06	Provided 06	MR
13	Pumping Arrangements. Common with Mall			
	➤ Ground Level	Required	Provided	M/R
	➤ Discharge of main Pump	2850 Lpm	2850 LPM	M/R
	➤ Head of Main pump	60m	60m	M/R
	➤ Number of main pumps	02	02	M/R
	➤ Jockey Pump out put	180 lpm x 2	180 lpm x 2	M/R
	➤ Jockey pump head	60m	60m	M/R
	➤ Standby Pump out put	2850 lpm	2850 lpm	M/R
	➤ Standby Pump Head	60m	60m	M/R
	➤ Auto Starting/ Manual stopping	Required	Provided	M/R
	➤ Pump House Access	Required	Provided	M/R
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting. common with mall			
	• Underground tank capacity	1,00,000ltrs	1,00,000ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 ltrs	30,000 ltrs	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided	MR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided (625 KVA)	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standard on the fire prevention and fire safety required under the rules, FSC issued vide letter no F6/MS/DFS/2006/1272 Dated: 07/06/2006 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name :- Rajesh Kumar
 Designation:- ADO/RN


DO/NWD

8 Singh
5.7.17

Dy CPO (W2)

CPO West

6/07/17


 5/7/17