

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2017/NDZ/ 1043

Dated: 14/7/17

FIRE SAFETY CERTIFICATE

Certified that the **Ryan International School**, Sector -B, Kondli Gharoli Complex, Mayur Vihar Ph-III, Delhi-92, comprised of basement, ground plus three upper floors was issued FSC vide letter No.- F6/MS/DFS/School/2013/1024 dated 04/10/13. The school building was inspected by the officer concerned of this department on 03/07/2017 in the presence of **Sh. Pankaj** (Care Taker) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class 'B' 'Educational Building' with effect from .....14/7/17.....for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....14/7/17..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

OK

To,

ThePrincipal,  
Ryan International School, Sector -B,  
Kondli Gharoli Complex, Mayur Vihar Ph-III, Delhi-96.

Copy to:-

The Director of Education,  
Government of N.C.T. Delhi,  
Old Sectt, Delhi-54.

## CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : Ryan International School, Sec-B, Kondli Gharoli Complex, Mayur Vihar Ph-III, Delhi-92.
2. Building is comprised of : Basements, ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6//MS/DFS/school/2013/NDZ/1024dt-04/10/13
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 03/07/17
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of officer from the building side : Sh. Pankaj (Care Taker)
10. Year of construction : 2002
11. Applicant's letter No : Dated- 31/05/2017

Sr No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 m	18 m	MR
		06 m	06 m	MR
		N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper floor</li> <li>• Basement</li> </ul>	03 Nos.	03 Nos.	MR
		03 Nos.	03 Nos.	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper floor</li> <li>• Basement</li> </ul>	1.5 m or less	1.47m, 1.46m & 1.42 m	MR
		1.5 m or less	1.47m, 1.46m & 1.42 m	MR
	c. Protection of Exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
	d. No. of Continuous Staircases to Terrace	02 No.	03 No.	MR
	e. Width of Corridor	1.5 m or less	1.8 m	MR
	f. Door Size	1.0 m	1.0 m	MR
	g. No. of Doors	02 Nos.	02 Nos.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire dampers</li> </ul>	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>	22 nos.	25 nos.	MR
		ABC /CO <sub>2</sub>	Provided	MR
		ISI marked	Provided	MR


3	First-Aid-Hose Reels.			
	• Total numbers on each floor	02 Nos.	02 Nos.	MR
	• Length of hose reel hose	30 mtr.	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N.A.	N.A.	N.A.
	• Location of main panel	N.A.	N.A.	N.A.
	• Location of repeater panel	N.A.	N.A.	N.A.
	• Alternate source of power	N.A.	N.A.	N.A.
	• Hooter's location	N.A.	N.A.	N.A.
8	MOEFA	N.A.	Provided	MR
09	Public Address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N.A.	N.A.	N.A.
	• sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 No.	Provided	MR
	• Hose box	02 No.	Provided	MR
2	Yard Hydrants.			
	• Total number of hydrants	04 Nos.	Provided	MR
	• Hose box	04 Nos.	Provided	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	900 LPM	900 LPM	MR
	• Head of main pump	40 M	40 M	MR
	• Number of main pumps	01 No.	01 No.	MR
	• Jockey pump out put	220 LPM	220 LPM	MR
	• Jockey pump head	40 M	40 M	MR
	• Standby pump out put	N.A.	N.A.	N.A.
	• Standby pump head	N.A.	N.A.	N.A.
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N.A.	N.A.	N.A.
	• Head of the pump	N.A.	N.A.	N.A.
	• Power supply	N.A.	N.A.	N.A.
	• Auto Starting of pump	N.A.	N.A.	N.A.
4	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 ltrs	50,000 ltrs	MR
	• Draw-off connection	Required	Required	MR
	• Fire service inlet	Required	Required	MR
	• Access to tank	N.A.	N.A.	N.A.
	• Overhead Tank capacity	15,000 Ltrs	15,000 Ltrs	MR
15	Exit Signage.	N.A.	N.A.	N.A.

NIG

16	Provision of Lifts.			
	<ul style="list-style-type: none"><li>• Pressurization of Lift Shaft</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• Pressurization of Lift lobby</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• Communication in lift car</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• Firemen's grounding switch</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• Lift Signage</li></ul>	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"><li>• Total area</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• Location</li></ul>	N.A.	N.A.	N.A.
19	Fire Control Room			
	<ul style="list-style-type: none"><li>• Detector system panel</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• Flow switch panel</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• PA system panel</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• Battery backup</li></ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"><li>• Building Floor Plans</li></ul>	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The building was issued shortcomings vide letter no. F6/DFS/MS/School/2017/655 dated 10/03/2017. The same were checked and found functional at the time of inspection ✓

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The NOC issued vide letter no. F6//MS/DFS/school/2013/NDZ/1024dt-04/10/13 renewal under the Circular of Director of Education date-17/01/05 is recommended to grant Fire Safety Certificate.



Signature of the Inspecting Officer

Name : R. K. Yadav

Designation : ADO(LN)

DY CPO (ND2)

