

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/FH/2017/WZ/ 1017

Dated: 13 / 7 / 2017

FIRE SAFETY CERTIFICATE

Certified that the The Jalsa Banquet Halls, at A-1/6, Paschim Vihar, Rohtak Road, New Delhi-63 comprised of Basement + stilt floor + Ground Floor + Three Upper Floors only, owned / occupied by The Jalsa Banquet Halls has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/2014/Banquet/WZ/886 dated 18/07/14. The premises was re-inspected by the officer concerned of Fire Service on 16.06.2017 in the presence of Sh. Ved Malhotra and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Assembly** (Group – D) with effect from 13 / 7 / 2017 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions printed below.

Issued on13/7/17..... at New Delhi.


(Atul Garg)
Chief Fire Officer,
oc

Copy to :-

1. Sh. Ved Malhotra, The Jalsa Banquet Halls, A-1/6, Paschim Vihar, Rohtak Road, New Delhi-110063.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in

N/17

INSPECTION REPORT

**Stilt + Basement + Ground +
Three Upper Floors**

Plot Area = 334.45 M²
 Covered Area of Basement = 256.41 M²
 Covered Area of Stilt = 286.14 M²
 Covered Area of G. Floor = 286.14 M²
 Covered Area of 1st Floor = 286.14 M²
 Covered Area of 2nd Floor = 286.14 M²
 Covered Area of 3rd Floor = 87.33 M²

1. Name & address of the building : **The Jalsa Banquet Halls,**
A-1/6, Paschim Vihar,
Rohtak Road, New Delhi-63.
2. Type of Occupancy : **Assembly**
3. Type of Case : **Renewal**
4. Details of previous NOC : Letter No **F6/DFS/MS/2014/Banquet/WZ/886 dated 18/07/14**
5. Fire Safety directives Letter No. : **F.6/DFS/MS/BP/2013/2591 dated 26.10.2013**
6. Date of inspection : **16.06.2017**
7. Name of the Inspecting Officer : **A.K. Jaiswal**
8. Name and designation of Officer
 from the building side : **Sh. Ved Malhotra (Partner)**
9. Year of Construction : **Before 2010**
10. Applicant's letter No. : **Nil**

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6.0 Mtr.	60 Mtr.	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.50 X 1 1.00X1	1.50 Mtr. 1.40 Mtr.	MR
	• Basements	1.50 X 1 1.00X1	1.50 Mtr. 1.40 Mtr.	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NP	NR
	d. No of continuous staircase to terrace	One	One	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2.00 Mtr x 2	2.00 Mtr x 2	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
		Required	Provided	MR

width of the main staircase is 1.50Mtr., and travel distance in Building is meeting the requirement, hence one additional Fire escape of 1.40Mtr. is sufficient as plot area is less than 500m².

N/18

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required	Provided	MR
		NR	NP	NR
		NR	NP	NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	Exhaust fan	MR
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	12	15	MR
	<ul style="list-style-type: none"> Types 	ABC/Co2	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	One	One	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mtr.	30 mtr.	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector 	Smoke	Smoke	MR
	<ul style="list-style-type: none"> Location of Main Panel 	GF	GF	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Each Floor	Each Floor	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	GF	GF	MR
8:	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NP	NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Not Required	Not Provided	NR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Not Required	Not Provided	NR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	100 mm	100 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	One	One	MR
	<ul style="list-style-type: none"> Hose Box 	One	One	MR

22

11/19

11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	100 mm	MR
	• Number of hydrants per floor	One	One	MR
	• Hose Box	One	One	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level / Over Head	O.H. Tank		
	• Discharge of main pump	2280 Lit/min.	2280 Lit/min.	MR
	➤ Head of main pump	40 Meter Head	40 Meter Head	MR
	➤ Number of main pumps	2	2	MR
	➤ Jockey pump out put	180 Lit/min.	180 Lit/min.	MR
	➤ Jockey pump head	40 Meter Head	40 Meter Head	MR
	➤ Standby Pump out put	2280 Lit/min.	2280 Lit/min.	MR
	➤ Standby Pump Head	40 Meter Head	40 Meter Head	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 Lit/min.	900 Lit/min.	MR
	➤ Head of the pump	40 Meter Head	40 Meter Head	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	NA (on terrace)	NA(on terrace)	NA (on terrace)
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	60,000 Ltr.	60,000 Ltr.	MR

AKS

N/20

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Not Required	NP	NR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.

F6/DFS/MS/2014/Banquet/WZ/886 dated 18/07/14 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Not:- * Management has provided 60,000 lts capacity Over Head Tank in place of 50,000 lts Under Ground Tank and 10,000 lts Over Head Tank. All the Pumps are mounted on Terrace / Roof Top.*

D.O. (w) on leave

~~Dyepo (w)~~

Ak Jaiswal
01/6/17

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (JwalaPuri)

CPD 12/1/14
19/6/17
Shank

19/6/17