

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/GH/SZ/2017/ 998

Dated: 11/7/17

FIRE SAFETY CERTIFICATE

Certified that **Hotel Kama Palace located at 9A/34, Channa Market, WEA, Karol Bagh, New Delhi- 110005** comprised of basement (storage), ground floor (reception, office & 04 guest rooms), first floor (06 guest room) and second floor (06 guest rooms) (total 16 guest rooms) and terrace floor (01 staff room & staff pantry) was granted FSC by this department vide letter No. F6/DFS/MS/GH/2014/SZ/1044 dated 21.08.2014. The premises was re-inspected by the officer concerned of this department on 30/06/2017 in presence of Mr. J.N.Chawla, CEO of the guest house and found that deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) for 16 guest rooms with effect from 11/7/17 for a period of three years in accordance with rule 35 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 11/7/17 at New Delhi by.

Vipen Kental
(VIPEN KENTAL)
CHIEF FIRE OFFICER

Copy to:-

1. The CEO, Hotel Kama Palace, 9A/34, Channa Market, WEA, Karol Bagh, New Delhi- 05.
2. The Joint C.P. (Lic.), Police Station, Defence Colony, 1st floor, New Delhi

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "F" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s. Hotel Kama Palace, 9A/34, Channa Market, WEA, Karol Bagh, New Delhi- 110005.
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2014/SZ/1044 dated 21.08.2014
5. Fire Safety directives letter No : Nil
6. Date of inspection : 30-06-2017
7. Name of the Inspecting Officers : M.K. Chattopadhyay, DO(South West)
8. Name and designation of officers from the building side : Dr. J.N.Chawla, Owner/Occupier
9. Year of Construction : 1996-97
10. Applicant's letter No. : 775/Addl. C.P./Lic. (H) dated New Delhi the 10.04.2017

The said guest house is comprised of basement (storage), ground floor (reception, office & 04 guest rooms), first floor (06 guest room) & second floor (06 guest rooms) and forth floor (01 staff room & staff pantry) (total 16 guest rooms).

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Existing fire safety requirements as per letter dated 21.08.2014	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case
	• Basements	01	01	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	1.25 mts	1.25 mts	MR being old case
	• Basements	1.25 mts	1.30 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	1.6 mts	MR
	h. Door Size	Old case	0.80 mts	MR being old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

	Basements	12 a/c per hour	provided	MR
	• Upper floors		Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	20	Provided	MR
	• Types	CO ₂ , ABC, WCO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
		N/A	N/A	N/A

	<ul style="list-style-type: none"> ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		-----	-----	-----
		450 LPM	450 LPM	MR
		30 mts	30 mts	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	----
		N/A	N/A	N/A
		5,000 lts	5,000 lts	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were checked and found functional at the

21/26
In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/GH/2014/SZ/1044 dated 21.08.2014, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

354/DOCSW
04.04/07/17

DCFO (SZ)

[Signature]
04/07/2017

Signature of the Inspecting Officer
Name M.K.CHATTOPADHYAY
Div. Officer (South West)

[Signature]
S/A



CFO SZ

m.scell

F-T/M.

W
7/7.

F-T. letter is put up for Signi. please.

10/6/CFO SZ
10/7

CFO (South)

[Signature]
10/7/17

m.scell

W
10/7.