

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. *F6/DFS/MS/school/2017/NDZ/1068* Dated: *20/7/17*

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Lovely Rose Public School located at C-9, Yamuna Vihar, Delhi 110053, comprised of ground plus two upper floors only owned/occupied by Lovely Rose Public School was issued FSC vide letter no. F6/DFS/MS/School/2013/NDZ/893 dated 10/09/13. The school building was re-inspected by the officer concerned of this department on 12/07/17 in the presence of Mr. S. C. Gupta, Admin Officer & Mrs. Kiran Bansal, Vice Principal of the school and observed that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter no. 262-362 dated 17/01/2005 issued by Director of Education and found that the school building is fit for occupancy class "B" 'Educational Building' with effect from ...*20/7/17*... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....*20/7/17*.....at New Delhi by



(Sunil Chawdhary)  
Dy. Chief Fire Officer

To,  
The Vice Principal  
Lovely Rose Public School,  
C-9, Yamuna Vihar,  
Delhi 110053

Copy:-  
The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi-110053

*o/c*  
*of*

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : M/s Lovely Rose Public Secondary School, C-9, Yamuna Vihar, Delhi-110053
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2013/NDZ/893, dated-10/09/13
6. Fire Safety directive letter No. : 262 – 362 dated 17/01/2005 (Director of Education)
7. Date of Inspection : 12/07/17
8. Name of the Inspecting officers : ADO Omprakesh
9. Name and designation of Officer from the building side : Mr. S.C. Gupta (Admin. Officer) & Mrs. Kiran Bansal(Vice Principal)
10. Year of Construction : 1988
11. Applicant's letter No : Letter No. LRPS/1155 dated 06/05/17

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 mtrs. 4.5 mtrs N/A	06 mts. 4.5 mtrs N/A	MR MR N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper floor</li> <li>• Basement</li> </ul>	02 No. N/A	02 No. N/A.	MR N/A
	b. Width of Staircases	1.50 mtr.	1.50 mtr.&0.90 mtr	MR
	<ul style="list-style-type: none"> <li>• Upper floor</li> <li>• Basement</li> </ul>	1.50 mtr. N/A	1.50 mtr.&0.90 mtr N/A	MR (old accepted) N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	01 No.	02No.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.&1.0 mtr.	MR
	f. Door Size	01 mtr.	1.16 mtr.	MR
	I No. of doors in class room	02 Nos.	01 No.	Accepted as no. of student less than 40
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	11 nos. ABC /CO <sub>2</sub> ISI marked	11 nos. ABC /CO <sub>2</sub> ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	01 no.	01 no.	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 mtr.	30 mtr.	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of main panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of repeater panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>upper floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> </ul>	100 mm	100 mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	01 no.	01 no.	MR
	<ul style="list-style-type: none"> <li>Hose box</li> </ul>	01 no.	01 no.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	01 no.	01 no.	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01 no.	01 no.	MR
13	Pumping Arrangements.	N/A	N/A	N/A
	➤ Ground Level	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Head of Main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Jockey pump out put</li> </ul>	180 lpm	180 lpm	MR
	<ul style="list-style-type: none"> <li>Jockey pump head</li> </ul>	40 mtr.	40 mtr.	MR
	<ul style="list-style-type: none"> <li>Standby pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Standby pump head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Auto Starting /Manual stopping</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump house access</li> </ul>	N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> </ul>	450 lpm	450 lpm	MR
	<ul style="list-style-type: none"> <li>Head of the pump</li> </ul>	40 M	40 M	MR
	<ul style="list-style-type: none"> <li>Power supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Auto Starting of pump</li> </ul>	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead tank capacity</li> </ul>	5,000 ltrs.	5,000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Firemen's grounding switch</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift signage</li> </ul>	N/A	N/A	N/A

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcomings communicated vide letter no. F6/DFS/MS/School/2017/16 dated 04/01/17 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular letter no. F16/Estate/CC/Fir Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education, it is recommended to issue Fire Safety Certificate.

*Omprakesh*  
13/7/17

Signature of the Inspecting Officer

Name :- Omprakesh

Designation :- A.D.O

DO(ED)

*[Signature]*  
14/7/17

DYCO/NDZ.

F. I. please