

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/EH/2017/SZ/ 1108

Dated: 26/7/17

**FIRE SAFETY CERTIFICATE**

Certified that the M/s **Dao Bed Lounge** (A Unit of Rara Premier Foods P Ltd) located at N-17, GF, FF & SF, N Block Market, Greater Kailash, New Delhi, comprised of basement, ground plus two upper floors (**Restt. running at First & Second floor of the building**) was granted FSC by this department in the name of M/s Dimcha Dao vide letter No. F.6/DFS/MS/ EH/2014/SZ/291 dated 03.03.2014. The premises was re-inspected by the officer concerned of this department on 10/07/2017 in the presence of Mr. Anil Chauhan (Manager) of the eating house and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Assembly Building**" (Eating House) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/7/17 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. M/S Dao Bed Lounge, N-17, N Block Market, Greater Kailash-I, New Delhi-110048
2. The DHO (CZ), South MCD, Health Deptt. Jal Vihar, Lajpat Nagar, New Delhi

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).


## INSPECTION REPORT

|       |   |   |                        |                |
|-------|---|---|------------------------|----------------|
| 1     | Name & Address of the Building                              | M/s Dao Bed Lounge, N-17, N Block Market, Greater Kailash-I, New Delhi-48<br>(A Unit of Rara Premier Foods P Ltd) |                        |                |
| 2     | Type of Occupancy   | Group-D "Assembly Building" (Restaurant)  |                        |                |
| 3     | Building Comprised of                                       | Basement, ground + 2 upper floors   |                        |                |
| 4     | Type of Case  | Renewal + Change of Name  |                        |                |
| 5     | Details of Previous NOC                                     | F.6/DFS/MS/EH/2014/SZ/291 Dated 03-03-2014  |                        |                |
| 6     | Fire Safety Directives Letter No                            | Nil   |                        |                |
| 7     | Date of Inspection  | 10.07.2017  |                        |                |
| 8     | Name of the Inspecting Officers                             | ADO R.N. Singh  |                        |                |
| 9     | Name & Designation of Officers from the building side       | Mr. Anil Chauhan (Manager)  |                        |                |
| 10    | Year of construction  | Restt. running at First & Second floor only   |                        |                |
| 11    | Applicant letter No.  | Nil dated Nil (C-15)  |                        |                |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old FSC (03/03/2014) requirements   | Provided at Site       | Remarks MR/NMR |
| 1     | <b>Access to Building.</b>                                  |   |                        |                |
|       | • Road width  | Required  | 6 mtr                  | MR             |
|       | • Gate width  | N/A   | N/A                    | N/A            |
|       | • Width of internal road                                    | N/A   | N/A                    | N/A            |
| 2     | <b>Number, width, type &amp; arrangement of exits</b>       |   |                        |                |
|       | <b>a. Number of Staircase</b>                               |   |                        |                |
|       | • Upper floors  | Two   | Two                    | MR             |
|       | • Basement floor  | N/A   | N/A                    | N/A            |
|       | <b>b. Width of Staircase</b>                                |   |                        |                |
|       | • Upper floors  | Required  | 1.50 & 1.25 mtr        | MR             |
|       | • Basement floor  | N/A   | N/A                    | N/A            |
|       | <b>c. Protection of exits</b>                               |   |                        |                |
|       | • Fire check door   | N/A   | N/A                    | N/A            |
|       | • Pressurization  | N/A   | N/A                    | N/A            |
|       | <b>d. No. of continuous staircase to terrace</b>            | Required  | One                    | MR             |
|       | <b>e. Width of corridor</b>                                 | N/A   | N/A                    | N/A            |
|       | <b>f. Door size</b>   | 2 mtr   | 2 mtr & 1.25 mtr       | MR             |
| 3     | <b>Compartmentation.</b>                                    |   |                        |                |
|       | • Fire check door.  | N/A   | N/A                    | N/A            |
|       | • Sealing of electrical shafts.                             | N/A   | N/A                    | N/A            |
|       | • Fire rating of shaft door.                                | N/A   | N/A                    | N/A            |
|       | • Water curtain   | N/A   | N/A                    | N/A            |
|       | • Fire dampers.   | N/A   | N/A                    | N/A            |
| 4.    | <b>Smoke Management system.</b>                             |   |                        |                |
|       | • Basement  | N/A   | N/A                    | N/A            |
|       | • Upper floors  | Required  | Exhaust fan provided   | MR             |
| 5.    | <b>Fire Extinguishers.</b>                                  |   |                        |                |
|       | • Total numbers   | ISI marked  | 10 No's                | MR             |
|       | • Types   |   | ABC-06, Co2-04         | MR             |
|       | • ISI Marking   |   | Provided               | MR             |
| 6.    | <b>First Aid Hose Reels.</b>                                |   |                        |                |
|       | • Total numbers on each floor.                              | Hose-reel   | One at alternate floor | MR             |
|       | • Length of hose-reel hose.                                 |   | 30 m                   | MR             |
|       | • Nozzle Diameter   |   | 05 mm                  | MR             |

M/s Dao Bed Lounge Restt, N-17, N-Block Market, Greater Kailash-I, New Delhi-48

|     |   |            |                        |     |
|-----|---|------------|------------------------|-----|
| 7   | <b>Automatic fire detection &amp; alarming system</b> |            |                        |     |
|     | • Type of detectors                                   | N/A        | N/A                    | N/A |
|     | • Location of Main Panel                              | N/A        | N/A                    | N/A |
|     | • Location of Repeater Panel                          | N/A        | N/A                    | N/A |
|     | • Alternate source of power                           | N/A        | N/A                    | N/A |
|     | • Hooter's location                                   | N/A        | N/A                    | N/A |
| 8.  | <b>MOEFA</b>  | Required   | Provided               | MR  |
| 9.  | <b>Public Address System</b>                          | N/A        | N/A                    | N/A |
| 10. | <b>Automatic Sprinkler System</b>                     |            |                        |     |
|     | • Basement  | N/A        | N/A                    | N/A |
|     | • Upper floors  | Required   | Provided               | MR  |
|     | • Sprinkler above false ceiling                       | N/A        | N/A                    | N/A |
| 11. | <b>Internal Hydrants.</b>                             |            |                        |     |
|     | • Size of Riser/Down-comer                            | Required   | 100 mm                 | MR  |
|     | • Number of Hydrant per floor                         | Required   | One at alternate floor | MR  |
|     | • Hose box.   | Required   | One at alternate floor | MR  |
| 12. | <b>Yard Hydrants.</b>                                 |            |                        |     |
|     | • Total number of hydrants.                           | N/A        | N/A                    | N/A |
|     | • 2. Hose box.  | N/A        | N/A                    | N/A |
| 13. | <b>Pumping arrangements.</b>                          |            |                        |     |
|     | • <b>Ground Level</b>                                 |            |                        |     |
|     | ➤ Discharge of main pump.                             | N/A        | N/A                    | N/A |
|     | ➤ Head of main pump.                                  | N/A        | N/A                    | N/A |
|     | ➤ Number of main pumps.                               | N/A        | N/A                    | N/A |
|     | ➤ Jockey Pump output.                                 | N/A        | N/A                    | N/A |
|     | ➤ Jockey Pump head.                                   | N/A        | N/A                    | N/A |
|     | ➤ Standby Pump output.                                | N/A        | N/A                    | N/A |
|     | ➤ Standby Pump head.                                  | N/A        | N/A                    | N/A |
|     | ➤ Auto Starting / Manual Stopping.                    | N/A        | N/A                    | N/A |
|     | ➤ Access to pump house                                | N/A        | N/A                    | N/A |
|     | • <b>Terrace Level</b>                                |            |                        |     |
|     | ➤ Discharge of pump.                                  | 450 LPM    | 450 LPM                | MR  |
|     | ➤ Head of pump.                                       | 40 mtr     | 40 mtr                 | MR  |
|     | ➤ Power supply.                                       | Required   | Provided               | MR  |
|     | ➤ Auto starting of pump.                              | Required   | Provided               | MR  |
| 14. | <b>Captive water storage for Fire Fighting.</b>       |            |                        |     |
|     | • Underground tank capacity.                          | N/A        | N/A                    | N/A |
|     | ➤ Draw-off connection.                                | N/A        | N/A                    | N/A |
|     | ➤ Fire Service Inlet.                                 | N/A        | N/A                    | N/A |
|     | ➤ Access to tank.                                     | N/A        | N/A                    | N/A |
|     | • Overhead tank capacity.                             | 10,000 Ltr | 10,000 Ltr             | MR  |
| 15. | <b>Exit Signage.</b>                                  | Required   | Provided               | MR  |
| 16. | <b>Provision of Lifts.</b>                            |            |                        |     |
|     | • Pressurization of lift shaft.                       | N/A        | N/A                    | N/A |
|     | • Pressurization of lift lobby.                       | N/A        | N/A                    | N/A |
|     | • Communication in lift car.                          | N/A        | N/A                    | N/A |
|     | • Fireman's switch.                                   | N/A        | N/A                    | N/A |
|     | • Lift signage.                                       | N/A        | N/A                    | N/A |
| 17  | <b>Standby Power Supply</b>                           | Required   | Provided               | MR  |
| 18. | <b>Refuge Area</b>                                    |            |                        |     |
|     | • Total area  | N/A        | N/A                    | N/A |
|     | • Location  | N/A        | N/A                    | N/A |

N/9

|   |  |     |     |     |
|---|--|-----|-----|-----|
| 19.   | <b>Fire Control Room.</b>  |     |     |     |
|   | • Detector System Panel.   | N/A | N/A | N/A |
|   | • Flow Switch Panel.   | N/A | N/A | N/A |
|   | • PA system Panel.   | N/A | N/A | N/A |
|   | • Battery backup   | N/A | N/A | N/A |
|   | • Building floor plan  | N/A | N/A | N/A |
| 20.   | <b>Special Fire Protection System for the Protection of special Risk, if any :</b> | N/A | N/A | N/A |
| <p>The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2014/SZ/291 Dated 03/03/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <p style="text-align: right;"> <br/> Signature of the Inspecting Officer<br/> Name : R.N. Singh<br/> Designation: ADO </p> |  |     |     |     |

M/s Dao Bed Lounge Restt, N-17, GF, FF & SF, N-Block Market, Greater Kailash-I, New Delhi-48

D.O. (SD)

*Amilash*  
22/6/12



*dy/cfo (S2)*

*Kang*  
27/6

*99/cfo/S2*  
*4-7/14/2/25/7*

*cfo (S2)*

*pl. speak*

*u*  
3/7.

*N.S.K.*