

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2017/SZ/ 1103

Dated: 26/7/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Japanese School** located at **Sector-A, Pocket- B & C, Vasant Kunj, New Delhi-110070** comprised of Ground + three upper floors having total 20 rooms was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/679 dated 04/06/2014. The premises was re-inspected by officer concerned of this department on 02/07/2017 in presence of Mr. Yogheendran (Admin) of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "**Educational Building**" Group-B, with effect from the date of issue of this certificate for a period of **Three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/7/17 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The Authorised Signatory, Japanese School,  
Sector-A, Pocket- B & C, Vasant Kunj, New Delhi-110070
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



## INSPECTION REPORT

1	Name & Address of the Building	Japanese School, Sector-A, Pocket- B & C, Vasant Kunj, New Delhi-110070		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + 3 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/679 dated 04-06-2014		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2013/435 dated 31-01-2013		
7	Date of Inspection	02.07.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Yogheendran (Admin)		
10	Year of construction			
11	Applicant letter No.	Nil dated Nil, ODD No. 6737 Dt. 19.05.2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC (04/06/2014) requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	1. Road width	Required	9 mtr	MR
	2. Gate width	Required	5 mtr	MR
	3. Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type arrangement of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors	Required	2 No's	MR
	2. Basement floor	-NA-	-NA-	-NA-
	<b>b. Width of Staircase</b>			
	1. Upper floors	1.50 m	1.50 mtr each	MR
	2. Basement floor	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircase to terrace</b>	Required	Two	MR
	<b>e. Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door size</b>	1 mtr	1 mtr (sliding door)	MR
3	<b>Compartmentation.</b>			
	1. Fire check door.	Required	Provided	MR
	2. Sealing of electrical shafts.	-NA-	-NA-	-NA-
	3. Fire rating of shaft door.	-NA-	-NA-	-NA-
	4. Water curtain	-NA-	-NA-	-NA-
	5. Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	1. Basement	-NA-	-NA-	-NA-
	2. Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	1. Total numbers		44 No's	MR
	2. Types	ISI Marked	ABC-30, Co2-14	MR
	3. ISI Marking		Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.		Two	MR
	2. Length of hose-reel hose.	Hose Reel	30 m	MR
	3. Nozzle Diameter		5 mm	MR



7	<b>Automatic fire detection &amp; alarming system.</b>			
	1. Type of detectors	-NA-	-NA-	-NA-
	2. Location of Main Panel	-NA-	-NA-	-NA-
	3. Location of Repeater Panel	-NA-	-NA-	-NA-
	4. Alternate source of power	-NA-	-NA-	-NA-
	5. Hooter's location	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>	-NA-	-NA-	-NA-
	1. Basement.	-NA-	-NA-	-NA-
	2. Upper floors	-NA-	-NA-	-NA-
	3. Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	1. Size of Riser / Down-comer	-NA-	100 mm	-NA-
	2. Number of Hydrant per floor	-NA-	One	-NA-
	3. Hose box.	-NA-	One	-NA-
12.	<b>Yard Hydrants.</b>			
	1. Total number of hydrants.	-NA-	-NA-	-NA-
	2. Hose box.	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	450 LPM × 2 & 180 LPM	MR
	➤ Head of pump.	40 mtr	70 mtr each	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	• <b>Underground tank capacity.</b>	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• <b>Overhead tank capacity.</b>	10,000 Ltr	10,000 Ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	1. Pressurization of lift shaft.	-NA-	-NA-	-NA-
	2. Pressurization of lift lobby.	-NA-	-NA-	-NA-
	3. Communication in lift car.	-NA-	-NA-	-NA-
	4. Fireman's switch.	-NA-	-NA-	-NA-
	5. Lift signage.	-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	1. Total area	-NA-	-NA-	-NA-
	2. Location	-NA-	-NA-	-NA-

19.	<b>Fire Control Room.</b>			
	1. Detector System Panel.	-NA-	-NA-	-NA-
	2. Flow Switch Panel.	-NA-	-NA-	-NA-
	3. PA system Panel.	-NA-	-NA-	-NA-
	4. Battery backup	-NA-	-NA-	-NA-
	5. Building floor plan	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No. F.6/DFS/MS/School/2014/SZ/679 dated 04/06/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*R.N. Singh*  
12/11/17

Signature of the Inspecting Officer  
Name : R.N. Singh  
Designation: ADO

Japanese School, Sector-A, Pocket- B & C, Vasant Kunj, New Delhi-110070

D.O. (SD)

*Anilans*  
6/1/17

*dy. do (SU)*

1033/CF-82  
12/12/24/17

*Kanp*  
10/17

*Chand S*

*m-sdell*

*11/17*

