

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001



No.F6/DFS/MS/School/2017/NDZ/ 1117

Dated: 28/07/17

FIRE SAFETY CERTIFICATE

Certified that the Aster Public School, Mayur Vihar Ph-1, Delhi-91, owned/occupied by Aster Public School, Comprised of ground plus three upper floors was granted NOC vide letter F6/MS/DFS/2008/2275( for G+2 floors) dated-08/08/08. The school building was inspected by the officer concerned of this department on 20/07/17 in the presence of Mrs. Sonia Khanna (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and ground plus three floors of building is fit for occupancy class B "Educational Building" with effect from 28/7/17 for a period of **three** years, subject to conditions printed overleaf.

Issued on 28/7/17 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  


To,

The Manager,  
Aster Public School, Mayur Vihar Ph-1, Delhi-91.

Copy to:-

1. The Dy. Director of Education,  
Anand Vihar, Delhi-92.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety certificate to the Director inform 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

- 12
1. Name & address of the building : Aster Public School, Mayur Vihar Ph-1, Delhi-91.
  2. Building is comprised of : Ground Plus three upper floors
  3. Type of Occupancy : Educational
  4. Type of Case : Addition/Alteration
  5. Details of Previous NOC letter : F6/MS/DFS/2008/2275 dated-08/08/08(for G+2 floors)
  6. Fire Safety Circular No. : 262-362 dated 17.01.2005
  7. Date of Inspection : 20/07/17
  8. Name of the Inspecting officers : ADO R.K. Yadav
  9. Name and designation of Officer from the building side : Mrs.Sonia Khanna (Principal)
  10. Year of Construction : 1994 & 2014
  11. Applicant's letter No : Dated 07/07/17

S N	Minimum Standards on fire prevention and fire safety U/R33	Circular requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 M	06 M	MR
		4.5 M	4.5 M	MR
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	01 No.	02 Nos.	MR
	B. Width of Staircases	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	1.5 M	1.50 M & 1.35 M	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
		1 Nos	1 Nos	MR
	g. Width of Corridor	1.5 M	1.8 M	MR
	h. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• types</li> </ul>	06 Nos.	06 Nos.	MR
		ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"> <li>• ISI marking</li> </ul>	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 No	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	1 No.	Provided	MR
	• Hose Box	1 No.	Provided	MR
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the Pump	40M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/A

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The NOC issued vide letter no. F6/MS/DFS/2008/2275 dated-08/08/08(for ground plus two upper floors) renewal under the Circular no.262-362(Director of Education) date-17/01/05 is recommended to grant Fire Safety Certificate.

R. K. Yadav  
20/7/17

Signature of the Inspecting Officer  
Name: R. K. Yadav  
Designation: ADO(LN)

DO (ED)

Submitted for approval please

D. K. F. O. Sh.

1  
for info  
21/7/17