

No. F.6 DFS/MS/School/2017/SZ/ 1140

Dated: 31/7/17

FIRE SAFETY CERTIFICATE

Certified that the **Shahi Public School** located at **3313, Street No-37, Tughlakabad Extension, New Delhi**, comprised of Basement, Ground + two upper floors was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/640 dated 27/05/2014. The premises was re-inspected by officer concerned of this department on 02/07/2017 in presence of Mr. Chander Rijhwani (Manager) of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with Dte of Education circular No. 262-362 dated 17-01-2005 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/7/17 at New Delhi by

⁴
21/7
(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Manager, Shahi Public School, 3313, Street No-37, Tughlakabad Extn., N. Delhi-19
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	SHAHI PUBLIC SCHOOL, 3313, Street No-37 Tughlakabad Extension, New Delhi-110019		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement, Ground + two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/640 dated 27-05-2014		
6	Fire Safety Directives Letter No	DOE Circular No. 262-362 dated 17/01/05		
7	Date of Inspection	02.07.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Ms. Chander Rijhwani (Manager)		
10	Year of construction	2005-06 <i>✓</i>		
11	Applicant letter No.	Nil dated 22/05/17, ODD No. 7296 Dt. 01.06.2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC (19/04/2010) requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Required	6 mtr	MR
	2. Gate width	-NA-	4 mtr	-NA-
	3. Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type arrangement of exits.			
	a. Number of Staircase			
	1. Upper floors	Required	2 No's	MR
	2. Basement floor	Required	2 No's	MR
	b. Width of Staircase			
	1. Upper floors	Required	1.20m & 1.28m	MR
	2. Basement floor	Required	0.93 & 1.05m	MR (old case)
	c. Protection of exits			
	1. Fire check door	-NA-	-NA-	-NA-
	2. Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	1. Fire check door.	-NA-	-NA-	-NA-
	2. Sealing of electrical shafts.	-NA-	-NA-	-NA-
	3. Fire rating of shaft door.	-NA-	-NA-	-NA-
	4. Water curtain	-NA-	-NA-	-NA-
	5. Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	1. Basement	Required	Exhaust fan provided	MR
	2. Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	1. Total numbers		08 No's	MR
	2. Types	ISI Marked	ABC-08	MR
	3. ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.		One	MR
	2. Length of hose-reel hose.	Hose Reel	30 m	MR
	3. Nozzle Diameter		5 mm	MR


7	Automatic fire detection & alarming system.			
	1. Type of detectors	-NA-	-NA-	-NA-
	2. Location of Main Panel	-NA-	-NA-	-NA-
	3. Location of Repeater Panel	-NA-	-NA-	-NA-
	4. Alternate source of power	-NA-	-NA-	-NA-
	5. Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	1. Basement.	Required	Provided	MR
	2. Upper floors	-NA-	-NA-	-NA-
	3. Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	1. Size of Riser / Down-comer	Required	100 mm	MR
	2. Number of Hydrant per floor	-NA-	One	-NA-
	3. Hose box.	-NA-	One	-NA-
12.	Yard Hydrants.			
	1. Total number of hydrants.	-NA-	-NA-	-NA-
	2. Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	450 & 180 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	5,000 Ltr	5,000 Ltr	MR
15.	Exit Signage.	-NA-	Provided	-NA-
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	-NA-	-NA-	-NA-
	2. Pressurization of lift lobby.	-NA-	-NA-	-NA-
	3. Communication in lift car.	-NA-	-NA-	-NA-
	4. Fireman's switch.	-NA-	-NA-	-NA-
	5. Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	1. Total area	-NA-	-NA-	-NA-
	2. Location	-NA-	-NA-	-NA-

19.	Fire Control Room. 1. Detector System Panel. 2. Flow Switch Panel. 3. PA system Panel. 4. Battery backup 5. Building floor plan	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	01 ABC type fire extinguisher provided near electrical panel	MR

The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under DOE circular, FSC issued vide letter No. F.6/DFS/MS/School/2014/SZ/640 dated 27/05/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.




Signature of the Inspecting Officer


Name : R.N. Singh

Designation: ADO


D.O. (SD)



dy. CFO (SZ)



1042/CF SZ
17/2/25/2



CFO (SZ)

M-Sell

F-101

14/7