

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/School/2017/SZ/ 1141

Dated: 31/7/17

FIRE SAFETY CERTIFICATE

Certified that the Govt. CO-Ed. Senior Secondary, Sector-6 Site-1, Dwarka, New Delhi-110075, Comprised of ground plus three upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2015/SZ/1416 dated 5.8.2015 for old Block. The said School building was re-inspected by the officer concerned of this department on 6.7.2017 in presence of Sh. Shree Kishan (Estate Manager) & Sh. Nitesh Rawat (Site Engineer). **Management has constructed one more Block namely New Block comprised of ground plus three upper floors** and have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Act 2007 & Rules 2010 and that the premises/building is fit for occupancy class B "Educational building" **For New Block comprised of ground plus three upper floors** with effect from...31/7/17..... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on31/7/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service


Copy to:-

1. The Deputy Director (Education), Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. The Assistant Engineer (E), Education (Maint.) Sub Division M1-1, PWD, ITI Campus Pusa, New Delhi-110012.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	Govt. Co-Ed. Sr. Sec. School , Sector-6, Dwarka, New Delhi-110075.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New (Ground plus three upper floors)		
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/747 dated 18.6.204 (Old Block)		
5	Fire safety directives letter No	UBBL 2016/DOE CIR. 1.3.2011		
6	Date of inspection	6.7.2017		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Shree Kishan (Estate Manager) & Sh. Nitesh Rawat (Site Engineer)		
9	Year of construction	2017		
10	Applicant's letter No.	54(SPS School)/PWD EDU. Maint. Divn. M1/2017-18	New Block G+3	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL 2016/DOE CIR. 1.3.20122	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	5.20 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Three	Three	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr.	1.68, 1.69, 1.70 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Three	Three	MR
	e. Width of corridor	1.50 Mtrs.	1.75 Mtrs.	MR
	f. Door size	1.20 Mtr.	1.20 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	12 a/c change			
			Natural Ventilation	MR

97411267382

	total numbers	(CO2 OR ABC) ISI Marked	Provided	MR
	Types		CO2, ABC	MR
	ISI marking		ISI Marked	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	Three	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	Provided (2 Nos.)	MR
	b. head of the pump	40 Meter	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	Provided	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR

11/10

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire Extinguisher provided near electric Panel MR			

Fire protection systems provided in the building were checked & found functional at the time of inspection. Keeping in view compliance of the minimum standards on fire prevention & Fire Safety requirements under the rules. Issuance of Fire Safety Certificate is recommended under rule 35 of the Delhi Fire Service Act 2007 & Rules 2010 for New Block comprised of Ground plus three upper floors.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
S.P. Bhardwaj
ADO (Dwarka)

469/DO/SW
12/7/17

~~DO/SW~~

[Signature]
12/7/17

~~DCFO (S2)~~

[Signature]
12/7

1057/CF/S2
24/7/17/31/17

CF/S2

M-Scell
FTM
12/7



FT is put up for signature please

~~CF/S2~~ M-Scell 12/7

S.P. Bhardwaj
12/7/17

9411267382