

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI- 110001

NO.F6/DFS/MS/School/2017/SZ/ 1143

Dated: 31/7/17

FIRE SAFETY CERTIFICATE

Certified that the Green View Public School, Dwarka Vihar, Kakrola Road, Najafgarh, New Delhi-110043, comprised of ground plus two upper floors was Issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2014/SZ/1040 dated 20.8.2014. The said school building was re-inspected by the officer concerned of this department on 22.6.2017 in presence of Sh. Mahavir Singh (Representative) and found that the Premises/Building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and that the building is fit for occupancy class B "Educational building" for **ground plus two upper floors** with effect from...31/7/17..... for a period of **three years**, in accordance with rule 36 unless renewed 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service, Rules 2010, printed overleaf.

Issued on31/7/17..... at New Delhi by

31/7/17.
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director (Education), Govt. of NCT of Delhi, old Secretariat, Delhi-110054.
2. Manager, Green View Public School, Dwarka Vihar, Kakrola Road, Najafgarh, New Delhi-110043.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Green View Public School, Dwarka Vihar, Kakrola Road, Najafgarh, New Delhi-110043. (Near Sector-16B, Dwarka)		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+2)		
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/1040 dated 20.08.2014		
5	Fire safety directives letter No	Directorate of Education: F-16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011		
6	Date of inspection	22.06.2017		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Mahavir Singh (Representative)		
9	Year of construction	2003, 2009		
10	Applicant's letter No.	GVPS/DFSH/2017/592 dated 26.5.2017		

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/DOE CIR. 1.3.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	9 Mtrs.	MR
	2) Gate width	4.50 Mtrs.	4.80 Mtrs. & 3.20 Mtrs. (2 Nos.)	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs. each	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	3 Nos.	3 Nos.	MR
	e. Width of corridor	N/A	1.50 to 2.35	MR
	f. Door size	1 Mtr.	1.05 to 1.10 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 a/c charge	Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	One No. Co2 OR ABC for every 300 Sq.Mtrs.	16 Nos.	MR
	Types	ISI Marked	Co2 & ABC	MR
	ISI marking		Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	3 Nos.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 Lpm.	450 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Lts.	10000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


4/11

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire extinguisher provided near electric meter.			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements as per DOE CIR. dated 1.3.2011, renewal of FSC issued vide letter no.F6/DFS/MS/School/2014/SZ/1040 dated 20.8.2014 for ground plus two upper floor is recommended under rule 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.


S.P. Bhardwaj
 ADO (Dwarka)

~~DOA~~
 416/DO/SW
 20/7/17

~~DOA~~
 20/7/2017

DCFO (S2)

~~DOA~~
 20/7



~~DOA~~

m-scull
 Pg 101,
 21/7.

FT is put up for signature please

1089/CF-S2
 21/7.

~~DOA~~
 28/7/17

~~DOA~~

m-scull
 27/7.