

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

1186

9/8/17

आवृत्ति सूची

आवृत्ति सूची के अंतर्गत निम्नलिखित पदों पर भर्ती करने हेतु आवेदन पत्रों का निम्नलिखित दिनांक तक प्राप्त होना आवश्यक है।

1. फायर फाइटर (अनुभवहीन) - 10

2. फायर फाइटर (अनुभवी) - 10

3. फायर फाइटर (अनुभवी) - 10

4. फायर फाइटर (अनुभवी) - 10

5. फायर फाइटर (अनुभवी) - 10

6. फायर फाइटर (अनुभवी) - 10

7. फायर फाइटर (अनुभवी) - 10

8. फायर फाइटर (अनुभवी) - 10

9/8/17

वे
9/8

0/8 ±

9. फायर फाइटर (अनुभवी) - 10

10. फायर फाइटर (अनुभवी) - 10

11. फायर फाइटर (अनुभवी) - 10

12. फायर फाइटर (अनुभवी) - 10

13. फायर फाइटर (अनुभवी) - 10

14. फायर फाइटर (अनुभवी) - 10

15. फायर फाइटर (अनुभवी) - 10

16. फायर फाइटर (अनुभवी) - 10

17. फायर फाइटर (अनुभवी) - 10

18. फायर फाइटर (अनुभवी) - 10

19. फायर फाइटर (अनुभवी) - 10

20. फायर फाइटर (अनुभवी) - 10

21. फायर फाइटर (अनुभवी) - 10

22. फायर फाइटर (अनुभवी) - 10

Name & address of the building	: Professor Apartment-Vikramshila (Index No.57D), AI Campus, Phase Khas, New Delhi-110016
2. Type of Occupancy	: Group-"A" Apartment Building (Flats)
3. Type of Case	: New [Basement (common), 4 Blocks of Ground + 7 Upper Floors]
4. Details of Previous NOC	:NA
5. Fire Safety directives letter No	: F6/DFS/MS/BP/2008/1626 dated 16/06/2008
6. Date of inspection	: 2/8/2017
7. Name of Inspecting Officer	: A. K. Malik
8. Name and designation of officers from the building side	: Sh. Darshan Lal, Executive Engg. (Electrical)
9. Year of Construction	: 2012
10. Applicant's letter No.	: SGA/03-001/Gen/419/2936 dated 25/07/2017, Outdoor diary no. 9163 dated 25/07/2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement (each Block)	Provided at site (each Block)	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	9m 5m 6m	Provided Provided Provided	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	Two Six	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.25m 1.25m	Each of 1.45m Each of 1.45m	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required NA	Provided NA	MR NA
	d. No. of continuous staircases to terrace	Two	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required Required NA NA	Provided Provided Provided NA NA	MR MR MR NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 ACPH 12 ACPH	M.V. + Exhaust Fans Natural Ventilation	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	108 No's ABC/W.CO ₂ /CO ₂ ISI marked	Provided 40/40/28Nos Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30m 5mm	Provided 30m 5mm	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel 	NA NA NA	NA NA NA	NA NA NA

	<ul style="list-style-type: none"> • Alternate source of power • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	NA	NA	NA
	<ul style="list-style-type: none"> • Basement • Ground Floor • Sprinkler above false ceiling 	NA	Provided	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100mm	100mm	MR
		One	Provided	MR
		One	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 LPM	900 LPM	MR
		70m	35m	MR(Old Case)
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity. 	NA	1,00,000 Lts	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		25,000 Lts	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	NA	NA	NA

- 2/19 -

Professor Apartment-Vikramshila (Index No.37B), IIT Campus, Hauz Khas, New Delhi-110016

	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risks, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. The shortcomings communicated vide letter dated 06/08/2014 found complied during the inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly FSC in shape of DFA is put up for approval.

Anilash
3/8/17

Signature of Inspecting Officer

Name:- A.K. Malik

Designation:-DO (SZ)

11/1/17
21/1/17

DY. CFO (SZ)

Lamp
3/8



CFO (SZ)

m.scell

FTM

U
4/8

Since F.P. is put up for Govt. please,

Anilash
8/8/17

DD (SZ)

CFO (SZ)

m.scell

U
9/8