

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/SZ/2017/ 1193

Dated: 10/08/17

FIRE SAFETY CERTIFICATE

Certified that M/s S.D.M.C. Nigam Pratibha Vidyalaya, Gautam Nagar, Niti Bagh, New Delhi-110049, comprised of ground plus two upper floors owned/occupied by South Delhi Municipal Corporation, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of this department on dated 29.07.17 in the presence of Mrs. Sunita Rani, Principal of the school and found that the school building is fit for occupancy class B 'Educational Building' with effect from 10/08/2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on 10/08/2017 at New Delhi by

(Vipin Kental)

Chief Fire Officer

T.No.011-23413990

To,

1. The Principal, S.D.M.C. Nigam Pratibha Vidyalaya, Gautam Nagar, Niti Bagh, New Delhi.
2. The Director of Education, S.D.M.C. Civic Centre, New Delhi.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s S.D.M.C. Nigam Pratibha Vidyalaya, Gautam Nagar, Niti Bagh, New Delhi-110049.
2	Type of Occupancy	Educational Building "B"
3	Type of case	New Case.
4	Details of previous NOC	Nil.
5	Fire safety directives letter No	F.16/Estate/CC/Fire safety/2011/3298 to 3398, Dated-01.03.11.
6	Date of inspection	29.07.2017.
7	Name of the inspecting Officers :	A.D.O. Vedpal.
8	Name and designation of officers from the building side	Mrs. Sunita Rani, Principal of the school.
9	Building Comprised of	Ground plus two upper floors only.
10	Year of construction	1990
11	Applicant's letter No.	Nil, Dated 05.07.2017.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per NBC/BBL-83/Director Education Circular	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	9m	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A		N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	02Nos.	02Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5m/75cm	1.40m(each)	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr	1Mtr	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
	Upper Floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	total numbers	06nos.	11nos.	MR
	Types	ABC & WCO2	ABC & Water CO2	MR
	ISI marking	ISI Mark	ISI Mark	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	01no.	01no.	MR
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	5mm	5mm	MR

7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450LPM	450LPM	MR
	b. head of the pump	40m	40m	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000Liters	10000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
		Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

h

n/12

19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under Circular of Director of Education dated 01.03.2011, it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010. Also it is submitted that the shortcomings communicated vide letter dated 19.05.2016 have been complied as noted at serial numbers 13.

Accordingly DFA is put up for your approval and signature please.

[Handwritten Signature]
1/8/17

Signature of the inspecting officer


Name: Vedpal

Designation : ADO

~~D.O. (S.D)~~

[Handwritten Signature]
2/8/17

~~1/68/CPA/17-10/17
7/8/17-10/17~~
By CPD(S2)



[Handwritten Signature]
2/8

CPD(S2)

Ampeaks FT letter

m-scell

4/8

FT letter is put up for sign please

~~CPD(S2)~~

m-scell

10/8

[Handwritten Signature]
8/8/17
ADO(S2)