

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/EH/2017/SZ/ 1175

Dated: 8/8/17

FIRE SAFETY CERTIFICATE

Certified that the restaurant **Summer House Café** (A Unit of Shaktiraj Hospitality Pvt Ltd) located at **First Floor & Terrace, DDA Shopping Complex, Aurobindo Place Market, Hauz Khas, New Delhi**, was granted FSC by this department vide letter No. F.6/DFS/MS/EH/2014/941 dated 30/07/2014. The premises was re-inspected by the officer concerned of this department on 29-07-2017 in the presence of Mr. Sanju Walia (Manager) and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class-D **“Assembly Building”** as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on _____ at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The DHO (SZ), South MCD, Health Deptt, Green Park, New Delhi-110016
2. M/s Summer House Cafe, First floor, Aurobindo Place Market, Hauz Khas, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC (14/10/2005) requirement	Provided at Site	Remarks MR/NMR
1	Name & Address of the Building	Summer House Cafe, First floor, DDA Shopping Complex, Aurobindo Place Mkt, Hauz Khas, N Delhi (A Unit of Shaktiraj Hospitality Pvt Ltd)		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant)		
3	Building comprised of	Ground + One upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	No.F6/MS/DFS/EH/2014/SZ/941 Dated 30-07-2014		
6	Fire Safety Directives Letter No	Delhi Fire Service Act-2007 and Rules 2010		
7	Date of Inspection	29-07-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Sanju Walia (Manager)		
10	Year of construction	2005-06	Restt. running at first floor & terrace of the building	
11	Applicant letter No.	DHO/SZ/2017/D-541 dated 13/07/2017		
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	N/A	Directly accessible from the road	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	Two	Two	MR
	• Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	• Upper floors	Required	1.57 & 0.75 mtr	MR (old case)
	• Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	1.44 mtr	MR (old case)
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Provided in kitchen	MR
5	Fire Extinguishers.			
	• Total numbers	ISI marked	14 No's	MR
	• Types		ABC-10 & Co2-04	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.		One	MR
	• Length of hose-reel hose.	Hose Reels	30 m	MR
	• Nozzle Diameter		5 mm	MR


7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Heat & Smoke	MR
	• Location of Main Panel	Required	1st floor (Reception)	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
8.	MOEFA / MCP's	Required	Provided	M/R
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	Required	Provided in Restt.	M/R
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	Required	100 mm	M/R
	• Number of Hydrant per floor	Required	One	M/R
	• Hose box.	Required	One	M/R
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	Provided	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Ltr	10,000 Ltr.	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19.	Fire Control Room.	• Detector System Panel.	N/A	N/A	N/A
		• Flow Switch Panel.	N/A	N/A	N/A
		• PA system Panel.	N/A	N/A	N/A
		• Battery backup	N/A	N/A	N/A
		• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	Required	One Co2 type fire extinguisher provided near electrical panel	N/A	

The Fire protection systems provided in the restaurant building were checked/ tested at random and found functional at the time of inspection.


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/EH/2014/SZ/941 dated 30-07-2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name : R.N. Singh
 Designation: ADO

Summer House Cafe, DDA Shopping Complex, Aurobindo Place Mkt, Hauz Khas, New Delhi


D.O (SD)


11/8/17

dy. CFO (S2)



11/8/17
dy. CFO (S2)


48

M. Seem

FT 101

4/8