

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2017/NDZ/1208

Dated: 14/08/2017

FIRE SAFETY CERTIFICATE

Certified that the Town Hill Public School located at A-203/17, Phase-10, Shiv Vihar Karawal Nagar, Delhi-110094, comprised of ground plus one upper floor, owned / occupied by Town Hill Public School was issued FSC vide letter no. F6/DFS/MS/School/2013/122 dated 26/03/2013. The school building was re-inspected by the officer concerned of this department on 28/07/17 in presence of Mr. Amal Kumar Panchal, Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3300 Dated 01/03/11 issued by the Director of Education and observed that the building is fit for occupancy class 'B' 'Educational Building' for with effect from ...14/8/17... for a period of three years, subject to conditions printed overleaf.

Issued on.....14/8/17..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to:

1. The Principal  
Town Hill public School  
A-203/17, Phase-10,  
Shiv Vihar Karawal Nagar,  
Delhi-110094
2. The Director of Education  
East Delhi Municipal Corporation,  
419,Udyog Sadan,  
Patparganj Industrial Area,  
Delhi-110092



- 1 Name & address of the building : Town Hill public School at A-203/17 phasr-10, Shive Vihar Karawal Nager , Delhi-94.
- 2 Building is comprised of : Ground Plus one upper floor
- 2 Type of Occupancy : Educational
- 3 Type of Case : Renewal
- 4 Details of Previous FSC letter : F.6/DFS/MS/School/2013/122 Dated:26.3.13
- 5 Fire Safety circular No :F.16/Easte/CC/FS/2011/3298 to 3398 Dated: 1/3/11
- 6 Date of Inspection : 28/07/17
- 7 Name of the Inspecting officers : ADO OM PRAKASH
- 8 Name and designation of Officer from the building side : Mr. Amal Kumar Panchal (Principal)
- 9 Year of Construction : 2006
- 10 Applicant's letter No : Nil dated 18.7.2017

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	06 Mtrs	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02	02	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5m	1.5m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.5	1.5	N/A
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	07 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	Provided	MR



6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	provided	M/R
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A



16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

in view of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules the FSC issued vide letter no.F6/DFS/MS/School/2013/122 Dated:23.03.13 grant under the circular no. F.16/Easte /CC/FS/ 2011/3298 TO 3398 Dated 1/3/11 is recommended to renewal Fire Safety Certificate.

*Om Prakash* 29/7/17

Signature of the Inspecting Officer  
Name: om Prakash  
Designation : ADO

*submitter for approval plan.*

DO(ED)

*for*  
31/7/17

*Dr CFO*

*[Signature]*  
31/7