

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2017 / *EH/WZ/1223*

Dated : *18/08/17*

FIRE SAFETY CERTIFICATE

Certified that the M/s **Bikanervala Foods Pvt. Ltd.** located at **103-105, 1st floor, Ring Road Mall, Sector-3, Rohini, Delhi-110085** Ltd in the premise comprised of basement, ground and 08 upper floors owned/ occupied by M/s **Bikanervala Foods Pvt. Ltd.** was issued fire safety certificate vide letter no. F.6/DFS/MS/EH/2014/WZ/989 dated 07.08.2014 and The premises was re-inspected by the officers concerned of this department on 26.07.2017 in the presence of **Sh. Nikesh Sharma, Manager** and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -D-5(Assembly)** occupancy with effect from *18/08/17* for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on *18/08/17*..... at New Delhi by

Atul Garg
(Atul Garg)

Chief Fire Officer
Ph-011-23414250

Copy to:-

1. The Dy. Health Officer, North MCD,
Civil Line Zone, Sec-5, Rohini, Delhi-110054.
2. The Manager , Bikanervala Foods Private Ltd,
103-105, 1st floor, Ring Road Mall, Sector-3
Rohini, Delhi -110085.

INSPECTION REPORT

1. Name & address of the building : M/s Bikanervala Foods Pvt. Ltd. at 103-105, 1st floor, Ring Road Mall, Sector-3, Rohini, Delhi-110085.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/EH/2014/WZ/989 dated : 07.08.2014
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 26/07/2017
7. Name of the Inspecting Officers : ADO/RN
8. Name and designation of officers
from the building side : Sh Nikesh Sharma, Manager
9. Year of Construction : 2007
10. Applicant's letter No. : Nil dated 04.07.2017

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p align="center">09m</p> <p align="center">4.5m</p> <p align="center">NA</p>	<p align="center">10m</p> <p align="center">4.5m</p> <p align="center">NA</p>	<p align="center">MR</p> <p align="center">MR</p> <p align="center">NA</p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p align="center">04 common with mall</p> <p align="center">NA</p>	<p align="center">04 common with mall</p> <p align="center">NA</p>	<p align="center">MR</p> <p align="center">NA</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p align="center">1.50m</p> <p align="center">NA</p>	<p align="center">1.50m x3 with Mall & 1.20m</p> <p align="center">NA</p>	<p align="center">MR</p> <p align="center">NA</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p align="center">Required</p> <p align="center">Required</p>	<p align="center">Provided with Mall</p> <p align="center">Provided with Mall</p>	<p align="center">MR</p> <p align="center">MR</p>
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	02 Exits	1.80m & 1.70m(Old case)	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door 	<p align="center">Required</p> <p align="center">Required</p> <p align="center">Required</p>	<p align="center">Provided with Mall</p> <p align="center">Provided with Mall</p> <p align="center">Provided with Mall</p>	<p align="center">MR</p> <p align="center">MR</p> <p align="center">MR</p>

	<ul style="list-style-type: none"> Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06nos	08nos	MR
		ABC/Co2	ABC-06 /Co2-02	MR
		Yes	Yes	MR
6	First-Aid Hose Reels. (Common with Mall)			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04	04	MR
		30 m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system. (Common with mall)			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/ Heat	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided with Mall	MR
9	Public Address System.	Required	Provided with Mall	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants (Common with mall)			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	100 mm	MR
		4	4	MR
		4	4	MR
12	Yard Hydrants. (with mall)			

	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements. (Common with Mall)			
	<ul style="list-style-type: none"> ➤ Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	4500 lpm	4500 lpm	MR
	<ul style="list-style-type: none"> ➤ Head of Main pump 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	02	02	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	180 lpm	180lpm	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	4500 lpm	4500 lpm	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power Supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	NA	NA
14	Captive Water Storage for fire fighting. common with mall			
	<ul style="list-style-type: none"> • Underground tank capacity 	2,20,000 ltrs	2,20,000 ltrs	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection 	Required	provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	provided	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	30,000 ltrs	30,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. (Common with Mall)			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	Required	Provided	MR
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication In lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> • Lift Signage 	Required	Provided	MR
17	Standby power supply	Required	Provided	MR

18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room (Common with mall)			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 989 dated 07.08.2014 under rule 35 of the Delhi Fire Service Rules 2010.

DO / NWSD on - m/R

DCFO (WZ)

CAO

14/8/12

16/9/11 FT PLD

14/08/12

Signature of the Inspecting Officer

Name: - Rajesh Kumar

Designation:- ADO/RN