

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/ CNG/2017/WZ/1248

Dated: 22/08/2017

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Dispensing Station located at Lok Nayak Puram, Site No.2, Bakarwala, New Delhi-110041, comprised of Single story Building owned /Occupied by Indraprastha Gas Limited was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2014/CNG/WZ/339 dated 10/03/14. The premises was re-inspected by the officer concerned of Fire Service on 05.08.2017 and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Rule 33 of Delhi Fire Service, Rules 2010, and that the building / premises is fit for occupancy Hazardous (Group J) with effect from 22/08/2017 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 22/08/17 at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER.

Copy to :-

1. Alok Sharma, Chief General Manager (Fire & Safety), Indraprastha Gas Limited, IGL Bhawan, Plot No. 4, Community Centre, R.K. Puram, Sec.-9, New Delhi-110022.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

N114

**INSPECTION REPORT** (Plot Area=1080m<sup>2</sup>)

To see the compliance of office letter No. F6/DFS/MS/CNG/1262/17.S.17  
 1. Name & address of the building: CNG Dispensing Station, Lok Nayak Puram, Plot No.-3, Site No. -2, Bakarwala, New Delhi-41.

2. Type of Occupancy : Hazardous
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/2014/CNG/WZ/339 dated 10/03/2014
5. Fire Safety directives Letter No. : F.6/DFS/MS/CNG/2013/2596 dated 27.11.2013
6. Date of inspection : 05.08.2017
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer  
 from the building side :
9. Year of Construction : 2013
10. Applicant's letter No. : IGL/F&S/2017/15/94/1 dated 28 June, 2017

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL/NBC (Part-IV) Requirements | Provided at site | Remarks MR/NMR |
|------|---|--------------------------------|------------------|----------------|
| 1.   | Access of building  | 6 mtr.                         | 30 mtr.          | MR             |
|      | • Road width  | NA                             | NA               | NA             |
|      | • Gate width  | NA                             | NA               | NA             |
|      | • Width of internal road                                    | NA                             | NA               | NA             |
| 2.   | Number, width, Type & Arrangements of exits                 |                                |                  |                |
|      | a. Number of staircases                                     | NA                             | NA               | NA             |
|      | • Upper floors  | NA                             | NA               | NA             |
|      | • Basements   |                                |                  |                |
|      | b. Width of staircases                                      | NA                             | NA               | NA             |
|      | • Upper floors  |                                |                  |                |
|      | • Basements   | NA                             | NA               | NA             |
|      | c. Protection of exits                                      | NA                             | NA               | NA             |
|      | • Fire check door   |                                |                  |                |
|      | • Pressurization  | NA                             | NA               | NA             |
|      | d. No of continuous staircase to terrace                    | NA                             | NA               | NA             |
|      | e. Width Of Corridor  | NA                             | NA               | NA             |
|      | f. Door Size  | 1.00 mtr.                      | 1.00 mtr.        | MR             |

A.K.J

N/15

|     |  |   |   |    |
|-----|--|---|---|----|
| 3.  | Compartmentation                             |   |   |    |
|     | • Fire check door                            | NA  | NA  | NA |
|     | • Sealing of electrical shafts               | NA  | NA  | NA |
|     | • Fire Rating of shaft door                  | NA  | NA  | NA |
|     | • Water Curtain                              | NA  | NA  | NA |
|     | • Fire Dampers                               | NA  | NA  | NA |
| 4.  | Smoke managements System                     |   |   |    |
|     | • Basements                                  | 30 a/c per hour   | NA  | NA |
|     | • Upper floors                               | 12 a/c per hour   | NA  | NA |
| 5.  | Fire Extinguishers                           |   |   |    |
|     | • Total numbers                              | 4 trolley 75 K.G. each, 10 K.G. ABC-10 & Co <sub>2</sub> -3 | 4 trolley 75 K.G. each, 10 K.G. ABC-10 & Co <sub>2</sub> -3 | MR |
|     | • Types                                      | ABC, Co <sub>2</sub> & Water Mist cum Foam Trolley          | Provided  | MR |
|     | • IS marking                                 | ISI marked  | Yes   | MR |
| 6.  | First – Aid Hose Reels                       |   |   |    |
|     | • Total numbers on each floor                | NA  | NA  | NA |
|     | • Length of hose reel hose                   | NA  | NA  | NA |
|     | • Nozzle diameter                            | NA  | NA  | NA |
| 7.  | Automatic fire detection and alarming system |   |   |    |
|     | • Type of detector                           | Flame & Hand held explosive meter                           | Provided  | MR |
|     | • Location of Main Panel                     |   |   |    |
|     | • Location of Repeater Panel                 | G.F.  | G.F.  | MR |
|     | • Alternate source of power supply           | NA  | NA  | NA |
|     | • Hooters' Location                          | Required  | Provided  | MR |
|     |  | NA  | NA  | NA |
| 8.  | MOEFA  | Required  | Provided  | MR |
| 9.  | Public Address System                        | NA  | NA  | NA |
| 10. | Automatic Sprinkler System                   |   |   |    |
|     | • Basement                                   | NA  | NA  | NA |
|     | • Upper Floor                                | NA  | NA  | NA |

*(Handwritten signature)*

|     |   |    |    |    |
|-----|---|----|----|----|
|     | <ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul> | NA | NA | NA |
| 11. | Internal Hydrants   |    |    |    |
|     | <ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>      | NA | NA | NA |
|     | <ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>  | NA | NA | NA |
|     | <ul style="list-style-type: none"> <li>• Hose Box</li> </ul>                      | NA | NA | NA |
| 12. | Yard Hydrants   |    |    |    |
|     | <ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>      | NA | NA | NA |
|     | <ul style="list-style-type: none"> <li>• Hose Box</li> </ul>                      | NA | NA | NA |
| 13. | Pumping Arrangements  |    |    |    |
|     | <ul style="list-style-type: none"> <li>• Ground Level / Over Head</li> </ul>      |    |    |    |
|     | <ul style="list-style-type: none"> <li>• Discharge of main pump</li> </ul>        | NA | NA | NA |
|     | ➤ Head of main pump   | NA | NA | NA |
|     | ➤ Number of main pumps  | NA | NA | NA |
|     | ➤ Jockey pump out put   | NA | NA | NA |
|     | ➤ Jockey pump head  | NA | NA | NA |
|     | ➤ Standby Pump out put  | NA | NA | NA |
|     | ➤ Standby Pump Head   | NA | NA | NA |
|     | ➤ Auto Starting/Manual stopping   | NA | NA | NA |
|     | ➤ Pump House Access   | NA | NA | NA |
|     | <ul style="list-style-type: none"> <li>• Terrace level</li> </ul>                 |    |    |    |
|     | ➤ Discharge of pump   | NA | NA | NA |
|     | ➤ Head of the pump  | NA | NA | NA |
|     | ➤ Power supply  | NA | NA | NA |
|     | ➤ Auto starting of pump   | NA | NA | NA |
| 14. | Captive water Storage for fire fighting   |    |    |    |
|     | <ul style="list-style-type: none"> <li>• Under ground tank capacity</li> </ul>    | NA | NA | NA |
|     | ➤ Draw of connection  | NA | NA | NA |
|     | ➤ Fire service inlet  | NA | NA | NA |

N117

|     |  |  |          |    |
|-----|--|--|----------|----|
|     | <ul style="list-style-type: none"> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul> | NA   | NA       | NA |
| 15  | Exit Signage   | NA   | NA       | NA |
| 16. | Provision of Lifts   |  |          |    |
|     | ➤ Pressurization of Lift Shaft   | NA   | NA       | NA |
|     | ➤ Pressurization of lift lobby   | NA   | NA       | NA |
|     | ➤ Communication in lift Car  | NA   | NA       | NA |
|     | ➤ Fireman's Grounding Switch   | NA   | NA       | NA |
|     | ➤ Lift Signage   | NA   | NA       | NA |
| 17. | Standby power supply   | NA   | NA       | NA |
| 18. | Refuge Area  |  |          |    |
|     | ➤ Total area   | NA   | NA       | NA |
|     | ➤ Location   | NA   | NA       | NA |
| 19. | Fire control room  |  |          |    |
|     | ➤ Detector system panel  | NA   | NA       | NA |
|     | ➤ Flow Switch Panel  | NA   | NA       | NA |
|     | ➤ PA System Panel  | NA   | NA       | NA |
|     | ➤ Battery backup   | NA   | NA       | NA |
|     | ➤ Building Floor Plans   | NA   | NA       | NA |
| 20. | <b>Special Fire Protection Systems for Protection of special Risks, if any:</b>                      | Fire Buckets filled with sand, No smoking boards displayed in Hindi & English, electrical wiring in metal conduit, MCB, Co2 flooding system. | Provided | MR |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2014/CNG/WZ/339 dated 10/03/2014** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.P. / (w)

*[Handwritten signature]*  
10/8/17

D.Y. GPO (WZ)

*[Handwritten signature]*  
16/8/17

*[Handwritten signature]*  
14/8/17

*[Handwritten signature]*  
8/8/17

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (JwalaPuri)

*[Handwritten signature]*