

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI


No. F6/DFS/MS/2017/EH/WZ/1236

Dated: 18/08/17

FIRE SAFETY CERTIFICATE

Certified that the M/s **Eleven Course (A Unit of Eleven Course Hospitality Pvt. Ltd.)**, located at **Unit No. 116 – 117, First Floor, NDM – II, Plot no. D – 1, 2, 3, Netaji Subhash Place, Pitampura, Delhi – 110034** was issued FSC vide Letter No. F6/DFS/MS/EH/2014/WZ/342 dated 11/03/2014. The NDM - II, Netaji Subhash Place has already issued FSC vide Letter No. F6/DFS/MS/2017/WZ/1012 dated 12/07/2017. The premises was re inspected by the officers concerned of this department on 01-08-2017 in the presence of Mr. Upander Kumar (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 18/08/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/08/17..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Authorized Signatory,
Eleven Course Hospitality Pvt. Ltd.,
Unit No. 116-117, First Floor, NDM – II, D – 1, 2, 3, Netaji Subhash Place,
Pitampura, Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: Eleven Course, Unit No. 116 – 117, First Floor, NDM – II, Plot no. D – 1, 2, 3, Netaji Subhash Place, Pitampura, Delhi – 110034.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (NDM-II already issued NOC vide F6/DFS/MS/2017/WZ/1012 dated 12/07/2017)
4. Details of previous NOC : no. F6/DFS/ MS/EH/2014/WZ/342 dated 11/03/2014
5. Fire Safety directives Letter No. : FSC Issued to the building
6. Date of inspection : 01-08-2017
7. Name of the Inspecting Officer : DO (West) & ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Upander Kumar (Manager)
9. Year of Construction : 2010
10. Applicant's letter No. : Nil Dated 13 Jul 2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 m NA NA	Provided NA NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> • Upper floors • Basements b. Width of staircases <ul style="list-style-type: none"> • Upper floors • Basements c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No of continuous staircase to terrace	2 NA 1.5m & 1.25m NA NA NA NA	04 Provided NA Provided (old case) NA Provided Provided NA	MR NA MR NA NA NA NA
	e. Width Of Corridor f. Door Size	NA 1.5m & 1m	NA 190cm & 120cm, 95cm (Old case)	NA MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA 12 a/c per hour	NA Provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	02 nos. each type DCP, CO2 & WCO2 ISI marked	Provided Provided	MR MR

6.	First – Aid Hose Reels	common with the mall		
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided at GF	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Not Required	NR	NR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants: common with the mall			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements: Common with the mall			
	• Ground Level	NA	2850 lpm	MR
	• Discharge of main pump	NA	110 m	MR
	➤ Head of main pump	NA	Provided	MR
	➤ Number of main pumps	NA	180 lpm	MR
	➤ Jockey pump out put	NA	110 m	MR
	➤ Jockey pump head	NA	2850 lpm	MR
	➤ Standby Pump out put	NA	110 m	MR
	➤ Standby Pump Head	NA	Provided	MR
	➤ Auto Starting/Manual stopping	NA	Provided	MR
	➤ Pump House Access	NA	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	The Main pump is provided in place of terrace pump	MR
	➤ Head of the pump	40 m	-do-	MR
	➤ Power supply	Required	-do-	MR
	➤ Auto starting of pump	Required	-do-	MR
14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	NA	2,00,000 litres	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10, 000 litres	20, 000 Litrs Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2014/WZ/342 dated 11/03/2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name Mukesh Verma

Designation DO (West)

Signature of the Inspecting Officer

Name Udai Vir Singh

Designation ADO (WP)

Mukesh Verma
3/18/17
Dy. WFO (W2)
C/O West
9/10/17
ft D/11

Udai Vir Singh
8/18/17