

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/Hospital/2013/W2/1243

Dated: 22 / 08 / 2017

FIRE SAFETY CERTIFICATE

Certified that Maharishi Valmiki Hospital at Pooth Khurd, Delhi-110039 comprised of Basement + Ground + three upper floors, owned / occupied by that Govt of NCT of Delhi was issued fire safety certificate by this department vide letter no. F6/DFS/MS/2013/Hospital/213 dated 26/04/2013 have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 05/08/2017 in the presence of Sh. Rajat Sharma JE (E) PWD and the building / premises is fit for occupancy Institutional C-2 the date of issue of this certificate for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule -38 of the Delhi Fire Service Rule, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The use of basement shall be in accordance with building bye laws
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

WWW.dfs.Delhigovt.nic.in

Issued on 22/08/17 at New Delhi by



(Atul Garg)

Chief Fire Officer

Ph: 011-23414250

9/10/17

Copy to :

1. The Medical Superintendent, Maharishi Valmiki Hospital at Pooth Khurd, Delhi-110039.
2. The Executive Engineer (E), Health Maintenance Electric Division (North), PWD GNCTD, Dr. B.S.A Hospital sector-6, Rohini, Delhi-85

INSPECTION REPORT

Old block

Basement + Ground + three upper floors

1. Name & address of the building : Maharishi Valmiki Hospital at Pooth Khurd, Delhi-110039
2. Type of Occupancy : Institutional C-2
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2013/Hospital/213 dated 26/04/2013
5. Fire Safety directives letter No : F.6/DFS/MS/BP/97/Hospital/965 dated 08/08/1997
6. Date of inspection : 05/08/2017
7. Name of the Inspecting Officers : ,DO (NW) & ADO (BW)
8. Name and designation of officers
from the building side : Sh. Rajat Sharma (JE Elect.) PWD
9. Year of Construction : 2002
10. Applicant's letter No. : 23(1)/EE(Elect)/HMED(North)/PWD2017-18/389 dated 06/06/2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9.0 mtr	9.0 mtr	MR
	• Gate width	5.0 mtr	7.5 mtr	MR
	• Width of internal road	6 mtr	6.0 mtr	NMR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	08	08	MR
	• Basements	05	05	MR
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	2.00 mtr	1.60 to 1.94 mtr	MR Being old case
	• Basements	2.00 mtr	1.60 to 1.94 mtr	MR Being old case
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	Required	Provided	MR
	g. Width of Corridor	1.25 mtr	Provided	MR
	h. Door Size	1.25 mtr	1.25 mtr	MR

Rajat Sharma

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR	
		Required	Provided	MR	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Natural ventilation provided	MR	
		12 a/c per hour	Provided	MR	
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	1 @ 300 m ²	47 / 120/ 78	MR	
			ABC / Co2/ Wtr	MR	
			ISI marked	Yes	MR
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	05	Provided	MR	
			30 m	Provided	MR
			5 mm	Provided	MR
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided	MR	
		on gr. floor	Provided	MR	
		Required	Provided	MR	
		Required	Provided	MR	
		Required	Provided	MR	
8	MOEFA	Required	Provided	MR	
9	Public Address System.	Required	Provided	MR	
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	MR	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	150 mm	Provided	MR	
		05	Provided	MR	
		Required	Provided	MR	

Signature

12	Yard Hydrants.			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	2850 LPM	Provided	MR
	➤ Head of Main pump	80 M	Provided	MR
	➤ Number of main pumps	02	Provided	MR
	➤ Jockey Pump out put	280 LPM	Provided	MR
	➤ Jockey pump head	80 M	Provided	MR
	➤ Standby Pump out put	2850 LPM	Provided	MR
	➤ Standby Pump Head	80 M	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 ltrs	1,00,000 ltrs	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltrs	20,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided.	MR
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR

Ali Sam

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no Letter No. F6/DFS/MS/2013/Hospital/213 dated 26/04/2013. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name


Designation


 DCFO (WZ)
 C/o West
 14/8/17

Signature of the Inspecting Officer

Name

Designation


 7/8/17
 400 (B/D)