

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


NO. F6/DFS/MS/School/2017/SZ/ 1250

Dated: 22/08/17

FIRE SAFETY CERTIFICATE

Certified that the SCSR Govt. SKV No.1, Palam Enclave , New Delhi-110045, having three blocks comprised of ground floor & Two blocks comprised of ground plus one upper floor was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2014/SZ/1039 dated 20.8.2014. The said School building was re-inspected by the officer concerned of this department on 27.7.2017 in presence of Smt.Renu Dua (Principal)& Sh. Uma Kant (Estate Manager) and found that management have constructed **two more blocks comprised of ground plus one upper floor & demolished one ground floor block which is not in existence** and have complied with the fire prevention and fire safety requirements in accordance Directorate of Education circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 1.3.2011 and that the premises/building is fit for occupancy class B "Educational building" **for two blocks comprised of ground floor & four blocks comprised of plus one upper floor each** with effect from..22/08/17... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on22/08/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Director (Education), Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. The Principal, SCSR Govt. SKV No.1, Palam Enclave, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal/ Addition of Blocks (Ground + One upper floor)		
4	Details of previous NOC	F6/MS/DFS/School/2014/SZ/1039 Dated 20.08.2014		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011.		
6	Date of inspection	27.07.2017		
7	Name of the inspecting Officers :	S.P. Bhardwaj ADO (Dwarka)		
8	Name and designation of officers from the building side	Smt. Renu Dua (Principal) & Sh. Umakant (Estate Manager)		
9	Year of construction	2005, 2010, 2016		
10	Applicant's letter No.	SCSR/SKV-1/500 dated 29.06.2017		

Earlier 2 Blocks Ground + 1 upper floor & 4 Blocks ground floor only	Presently: 2 Blocks ground floor only (A & F-2) & 4 Blocks: Ground + One upper floor B, C, D, F1)
--	--

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. Dated 1.3.2011	Provided at site	Remarks MR / NMR
--------	---	-------------------------	------------------	------------------

1 Access to building

1) Road width	6 Mtrs.	30 Mtrs.	MR
2) Gate width	4.5 Mtrs.	4.47 & 3.67 Mtrs.	MR
3) Width of internal road	N/A	N/A.	N/A

2 Number, width Type & arrangement of exits

a. Number of staircases			
1. Upper floors	7 Nos.	7 Nos.	MR
2. basements	N/A	N/A	N/A
b. Width of staircase			
1. Upper floors	1.5 Mtrs.	B Block: 2 Mtr. & 1.50 Mtr. C Block: 1.55 Mtr. & 1.56 Mtr. D Block: 1.55, 1.56 Mtr. F-1 Block: 1.50 Mtr.	MR
2. basements	N/A	N/A	N/A
c. Protection of exits			
1. Fire check door	N/A	N/A	N/A
2. Pressurization	N/A	N/A	N/A
d. No. of continuous staircase to terrace			
	4 Nos.	4 Nos.	MR
e. Width of corridor	1.50 Mtr.	1.64 to 1.78	MR
f. Door size	1 Mtr.	1 Mtr. to 1.20 Mtrs.	MR

3 Compartmentation.

1. Fire check door	N/A	N/A	N/A
2. Sealing of electrical shafts	N/A	N/A	N/A
3. Fire Rating of shaft door	N/A	N/A	N/A
4. water curtain	N/A	N/A	N/A
5. Fire dampers	N/A	N/A	N/A

4 Smoke Management system.

basement	30 a/c per hour	N/A	N/A
	12 a/c per hour		
upper floors		Natural Vent.	MR

5 Fire Extinguishers

total numbers		28 Nos.	MR
Types		CO2 & ABC	MR
		Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A		N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/18

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: provided near electric panel	CO2 fire extinguisher MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Cir. dated 1.3.2011, grant of Fire Safety Certificate is recommended **for 2 Blocks comprising ground floor only & 4 Blocks comprising ground plus one upper floor** earlier Fire Safety Certificate issued vide letter no.F6/DFS/MS/School/2014/SZ 1039 dated 20.8.2014 for three blocks of Ground floor & two blocks of ground plus one upper floor.

Accordingly DFA is put up for your approval and signature please.

S.P. Bhardwaj
28/7/17
Signature of the Inspecting Officer
Name S.P. Bhardwaj ADO (DWK)

543/D.O. (CWO)
31.07.17


D.O. (CWO)

[Signature]

Dy. CFO (SZ)

11211 CF/SZ
19/8/17-21/18

[Signature]
7/8



CFA SZ

M. S. Cell *16/8*

FT is put up for signature plan.

S.P. Bhardwaj
11/8/17

CFA SZ *M. S. Cell* *16/8*