

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.F6/DFS/MS/Club/SZ/2017 /1260

Dated: 23/08/17

FIRE SAFETY CERTIFICATE

Certified that M/s Panch Shila Club, located at Panch Shila Park, New Delhi-110017, comprised of basement, ground plus one upper floor only, owned/occupied by The Panch Shila Co-op. H. B. Society Ltd, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2014/Club/SZ/812, dated 30-06-14. The premises was re-inspected by the officer concerned of this department on 05-08-2017 in the presence of Sh. Asha Ram Badola, Manager and found that the said club premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly (Club Building) with effect from 23/08/2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on 23/08/2017 at New Delhi by


(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy to:- 1. The Joint Commissioner of Police (Lic), 1st Floor, PS Defence Colony, New Delhi. o/c
2. Secretary, M/s Panch Shila Club, located at Panch Shila Park, New Delhi-110017. h

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Panch Shila Club, located at Panch Shila Park,
New Delhi-110017.
2. Building is comprised of : Basement, ground plus one upper floor only.
3. Type of Occupancy : Club Building (Assembly Occupancy i.e. Eating House).
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/2014/Club//SZ/812, dated 30.06.2014.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 05.08.2017.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer
from the building side : Sh. Asha Ram Badola (Manager).
10. Year of Construction : 2009-2010.
11. Applicant's letter No : No. PSC/DFS/179/2017, Dated 21.07.17.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements as per old NOC dt 30.06.2014	Provided at Site	Remarks
1	Access to building			
	Road width	Accessible	12m	MR
	Gate width	4.5m	4.5m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	Required	Provided	MR
	Upper Floor	02nos.	03nos.	MR
	Basement	01no.	01no.	MR
	B. Width of Staircases	Required	Provided	MR
	Upper Floor	1.5m(each)	1.5, 1.25 & 0.97m	MR(old case)
	Basement	Required	1.10m	MR(old case)
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01no.	02nos.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	N.A.	N.A.	N.A.
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fans Provided	MR
	Upper floor	12 a/c per hour	Exhaust fans Provided	MR
5	Fire Extinguisher			
	Total numbers	08 nos.	10 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on each floor	02nos.	02nos.	MR
	Length of hose reel hose	30m.	30m Provided	MR
	Nozzle diameter	5mm	5mm Provided	MR
7	Automatic fire detection and alarming system.			

6. Fire Safety direction letter No : Nil.
 7. Date of Inspection : 05.08.2017.
 8. Name of the Inspecting Officers: : Vedpal (ADO)
 9. Name and designation of Officer
 from the building side : Sh. Asha Ram Badola (Manager).
 10. Year of Construction : 2009-2010.
 11. Applicant's letter No : No. PSC/DFS/179/2017, Dated 21.07.17.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements as per old NOC dt 30.06.2014	Provided at Site	Remarks
1	Access to building			
	Road width	Accessible	12m	MR
	Gate width	4.5m	4.5m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	Required	Provided	MR
	Upper Floor	02nos.	03nos.	MR
	Basement	01no.	01no.	MR
	B. Width of Staircases	Required	Provided	MR
	Upper Floor	1.5m(each)	1.5, 1.25 & 0.97m	MR(old case)
	Basement	Required	1.10m	MR(old case)
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01no.	02nos.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	N.A.	N.A.	N.A.
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fans Provided	MR
	Upper floor	12 a/c per hour	Exhaust fans Provided	MR
5	Fire Extinguisher			
	Total numbers	08 nos.	10 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on each floor	02nos.	02nos.	MR
	Length of hose reel hose	30m.	30m Provided	MR
	Nozzle diameter	5mm	5mm Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR

10	Basement upper floor	Required	Provided	MR
	sprinkler above false ceiling	Required in Kitchen & restaurant area at 1 st floor	Provided	MR
		N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	02nos.	02nos.	MR
	Hose Box	02nos.	02nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900& 180LPM	900& 180LPM	MR
	➤ Head of the Pump	40m	40m(each)	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	On ground tank capacity	35000Liters.	3500Liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	15000Liters.	15000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

N125

M/s Panch Shila Club at Panch Shila Park, New Delhi-17

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/Club/2012/3300, dated 10.09.2012 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration and necessary approval please.

[Handwritten signature]
8/8/17

Signature of the Inspecting Officer

Name : Vedpal

Designation: Assistant Divisional Officer

~~D.O. (S.D.)~~

[Handwritten signature]
8/8/17

[Handwritten signature]

[Handwritten signature]
31/8

[Handwritten signature]

of all the shortcomings communicated earlier are complied with

[Handwritten mark]

