

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2017/SZ/ 1271

Dated: 24/08/17

FIRE SAFETY CERTIFICATE

Certified that the **St. Peter's Convent**, Block 'C', Vikas Puri, New Delhi-110018 comprised of basement, ground floor plus two upper floors, owned/occupied by St. Peter's Convent was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2014/SZ/1067 dated 26.08.2014. The School building was re-inspected by the officer concerned of this department on 09.08.2017 in the presence of Sh. Yashpal (Maintenance Head) and found that the St. Peter's Convent have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....24/08/17..... at New Delhi.

(VIPIN KENTAL)  
CHIEF FIRE OFFICER

23/8  
21/8/17

Copy to:-

1. The Principal,  
St. Peter's Convent, Block 'C',  
Vikas Puri, New Delhi-110018
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



### INSPECTION REPORT

1. Name & address of the building : St. Peter's Convent, Block 'C', Vikas Puri, New Delhi-110018 .
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2014/SZ/1067 dated 26.08.2014
5. Fire Safety directives letter No : N/A
6. Date of inspection : 09.08.2017
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Yashpal (Maintenance Head)
9. Year of Construction : 1986
10. Applicant's letter No. : Nil dated 28.06.2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 26.08.2014	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible (06 mtrs.) 4.5 mtrs N/A	09 mtrs Directly accessible from road N/A	MR MR N/A
<b>2.</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 No's	02 No's	MR
		02 No's	03 No's	MR
	b. Width of staircases	150 cms/additional staircase of 75 cms if less than 150 cms	105 & 75 cms GF to SF & 114 cms GF to FF	MR, being old case
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	150 cms/additional staircase of 75 cms if less than 150 cms	205, 90 & 75 cms	MR, being old case
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One	MR
	e. Width of Corridor	150 cms	175 cms	MR
	f. Door Size	100 cms	85/90 cms (Single door)	MR, being old case
<b>3.</b>	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Exhaust fans are provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	Required	Natural ventilation	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	20 no.'s	Provided	MR
		ABC/CO <sub>2</sub> type	Provided	MR
		ISI marked	ISI marked	MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One	Provided	MR
		30 mtrs	Provided	MR
		5 mm	Provided	MR



Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	Provided	N/A
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Ground Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N/A	100 mm	N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	One	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	One	N/A
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	450 LPM & 180 LPM	Provided	MR, being old case
		40 mtrs	Provided	MR
		Required	Provided	MR
		N/A	Provided	N/A
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
		5000 ltrs	5000 ltrs provided	MR, being old case
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	Provided	N/A
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A



19.	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2014/SZ/1067 dated 26.08.2014 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- As per undertaking given by the HOS (placed at C-18) seating capacity of classrooms is not more than 45 students & the basement in the premises is only being used for storage purpose.

*Sandeep*  
*10/8/17*

Signature of Inspecting Officer  
Name:- Sandeep Duggal  
Designation:- Asstt. Divisional Officer

*570/2018w*  
*10/8/17*

D.O. (South West)

*[Signature]*  
*10/8/17*

*DCFO (2)*

*1159/c/s*  
*24/8*

*[Signature]*  
*24/8*



*UO s/s*

*m.scell*

*FT 107*  
*16/8*

*F.T. letter is put up for signature please.*

*Sandeep*  
*21/8/17*

*UO (87)*

*m.scell*

*16/8*