

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2017 / CH/W2/1279

Dated 25/8 / 2017

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Burger King** located at **ground floor, Unit No-01,D-Block, Metro Walk, Sec-10, Rohini, Delhi-110085** in the building comprised of ground floor only owned/occupied by **M/s Burger King Pvt. Ltd.** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of Fire Service on 18.08.2017 in the presence of **Sh Mani Shanker, Executive Manager** and that the building/ premise is fit for occupancy Class Assembly for ground floor only with effect from 25/08/17 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on ...25.08.17..... at New Delhi by

  
(Atul Garg)

Chief Fire Officer  
Ph-011-23414250

Copy to:-

1. The Dy. Health Officer, North MCD,  
Civil Line Zone,Sec-5, Rohini, Delhi-110054.
2. The Manager , M/s Burger King Unit No-01,D-Block,  
Metro Walk, Sec-10 Rohini, Delhi-110085

**INSPECTION REPORT**

Ground floor only

1. Name & address of the building : M/s Burger King Unit No-01,D-Block, Metro Walk, Sec-10, Rohini, Delhi-110001.
2. Type of Occupancy : Assembly
3. Type of Case :New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 18/08/2017
7. Name of the Inspecting Officers : ADO/RN
8. Name and designation of officers from the building side : Mr. Mani Shanker, Executive Manager
9. Year of Construction :2017
10. Applicant's letter No. :DHO/RZ/2017/881 dated 31.07.2017

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09m	09m	MR
	• Gate width	06m	06m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	01	01	MR
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	02 Exits	2m each	MR
	f. Door Size			
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA

	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	06nos	08nos	MR
	• Types	ABC/Co2	ABC-06 /Co2-02	MR
	• IS marking	Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01(G. Floor)	01	MR
	• Length of hose reel hose	30 m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke/ Heat	Provided	MR
	• Location of Main Panel	GF	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Common area's	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12	<b>Yard Hydrants. (with mall)</b>			
	• Total number of hydrants	NA	Provided	NA

	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	Provided	NA
13	<b>Pumping Arrangements. (Common with Amusement Park)</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul>			
		4500 lpm	4500 lpm	MR
		40m	40m	MR
		02	02	MR
		180 lpm	180lpm	MR
		70m	70m	MR
		4500 lpm	4500 lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul>			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	<b>Captive Water Storage for fire fighting. (Common with Amusement Park)</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	1.25 lack x 02 ltrs	1.25lack x 02 ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		25000 ltr. x 02	25000 ltr. x 02	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			

