

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/Hospital/2017/NDZ/ 1311

Dated: 30.08.2017

FIRE SAFETY CERTIFICATE

Certified that the **Jeevan Anmol Hospital**, Mayur Vihar, Phase-1, Opp. Pratap Nagar, Delhi, comprised of basement, ground plus three upper floors was granted fire safety certificate vide letter no. **F6/DFS/MS/Hospital/2014/NDZ/476 Dated 16/04/14**. The Hospital was inspected by the officer concerned of this department on 10/08/17 & 18/08/17 in the presence of **Dr. Neera Sondhi (Dy. M.S)** and found that the Hospital have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rule 2010 and that the building is fit for occupancy Class C "Hospital (Institutional Building)" with effect from 30.08.2017 for a period of **three** years, subject to conditions printed overleaf. ♦

Issued on 30.08.2017 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer



To,  
Dr. Neera Sondhi (Dy.M.S)  
Jeevan Anmol Hospital, Mayur Vihar,  
Phase-1, Opp. Pratap Nagar, Delhi.

Copy to:-  
The Director of Health Services,  
M.O I/C Nursing Home Cell,  
Govt. of NCT Delhi, F-17 Karkardooma, Delhi.

N/18  
**INSPECTION REPORT**

1. Name & address of the building : Jeevan Anmol Hospital, Mayur Vihar, Phase-1, Opp. Pratap Nagar, Delhi
2. Building is comprised of : B+G+3
3. Type of Occupancy : Institutional Building
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/Hospital/2014/NDZ/476 Dated 16/04/14
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 10/08/17 & 18/08/17
8. Name of the Inspecting Officers : ADO R.K.Yadav
9. Name of the designation of Officer  
from the building side : Dr. Neera Sondhi (Dy.M.S)
10. Year of Construction : 2000
11. Applicant's letter No : Nil dated 24/07/17

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement /NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	9 m	13 m	MR
	Gate width	4.5 m	5 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no	2 no +01 ramp	MR
	Basement	2 no + 1 ramp	2 no + 1 ramp	MR
	B. Width of Staircases			
	Upper Floor	2 m	One no. of 2.0m ✓ & one no. of 1.80 m & 2.3 m Ramp ✓	MR
	Basement	1.5 m	2 M, 1.80 m & 1.5 m Ramp	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	2 no.	2 no.	MR
	g. Width of Corridor	2 m	2 m	MR
	h. Door Size	1 m	1m, 2m	MR
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Required	Provided	MR
	Upper floor	Required	Provided	MR

5.	Fire Extinguisher			
	Total numbers	20 no.	52 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	02 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Smoke	Smoke	MR
	Location of main panel	Required	Provided in fire control	MR
	Location of repeater panel	Required	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters's location	Required	Provided near staircase	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	2 no.	2 no.	MR
	Hose Box per floor	2 no.	2 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	03 no	MR
	Hose Box	N.A.	03 no.	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main Pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby pump out put</li> <li>➤ Standby pump Head</li> <li>➤ Auto Starting /Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace Level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the Pump</li> <li>➤ Power supply</li> <li>➤ Auto Starting of pump</li> </ul>			
		1680 LPM	1680 LPM	MR
		88 m	88 m	MR
		01 no.	01 no	MR
		180 LPM	180LPM	MR
		88 m	88 m	MR
		1680 LPM	1680 LPM	MR
		88 m	88 m	MR
		Required	Provided	MR
		Required	Provided	MR
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	1,00,000 Liters	1,15,000 Liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	20,000 Liters	25,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	Required	Provided	MR
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	Provided Local Application	MR

The building was issued shortcomings vide letter no. F6/DFS/MS/Hospital/2017/1053 dated 25/04/17 which is rectified. The same were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*R. K. Yadav*  
23/8/2017

Signature of the Inspecting Officer

Name : R. K. Yadav

Designation : ADO(LN)

Submitter for approval plan

~~DO/ED~~

225/CFE No 2  
28/8

DUCFB/NDY

*[Signature]*  
23/8/17

C.F.P - miscell

FTM.

*[Signature]*  
28/8