

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS; DELHI FIRE SERVICE, NEW DELHI-110001.**

No.F6/DFS/MS/Hospital/2017/ SZ /1281

Dated: 25/08/17

**FIRE SAFETY CERTIFICATE**

Certified that the Maharaja Agrasen Hospital ( A unit of Maharaja Agrasen Hospital Cheritable Trust), Plot No.1, Sector-1, Dwarka, New Delhi comprised of three tier basements, ground plus six upper floors was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/Hospital/2015/SZ 1470 dated 31.3.2015 for **three tier basements & ground floor only**. The said Hospital building was re-inspected by the officers concerned of this department on 9.8.2017 in presence of Sh. Narinder Dagar ( Admn.) and found that the premises/building have complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the premises/building is fit for occupancy class C-1 "Institutional Building" (Hospital) for **six upper floors** with effect from ...25/08/17..... for a period of **Three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on .....25/08/17..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Authorized Signatory, Maharaja Agrasen Hospital, Plot No.1, Sector-1, Dwarka, New Delhi.
2. The Jt. Director (L&I) DDA, Vikas Sadan, INA, New Delhi.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

