

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2017 / *School/WZ/1274*

Dated: *28/08* /2017

FIRE SAFETY CERTIFICATE

Certified that the **New Skyland Public School, B-Block, Avantika, Sec-1, Rohini , Delhi-85** comprised of **Ground and 02 upper floors** owned/ occupied by **New Skyland Public School** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2014/School/WZ/1274 dated 13.10.2014**. The premise was re-inspected by the officer concerned of this department on **14.08.2017** in the presence of **Smt. Anita Sharma, Principal** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from *28/08/17*..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on*28/08/17*..... at New Delhi


(Atul Garg)

Chief fire officer

Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, New Skyland Public School, B-Block, Avantika, Sec-1, Rohini , Delhi-85.

INSPECTION REPORT

1. Name & address of the building : New Skyland Public School, B-Block, Avantika, Sec-1, Rohini , New Delhi-85
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**G+02 floors**)
4. Details of previous NOC : F6/DFS/MS/2014/School/WZ/1274 dated 13.08.14
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 14/08/2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh. Anita Sharma / Principal
9. Year of Construction : 2000
10. Applicant's letter No. : NSPS/ND/2017-2018/21 Dated 12.07.2017

Plot Area-200 Sq.yard Covered area ----160 sq.yard No of student—198 nos, Total class room –09 nos
 Minimum Standards on fire prevention and fire safety U/R 33 NBC Requirement Provided at site Remarks MR/NMR

		NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	05m(old case)	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m	1.35m & 1.10m	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	01	01	MR	
e. Width of Corridor	NA	NA	NA	

	f. Door Size	1.0m	1.0m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements • Upper floors	30 a/c per hour	No basement	NA
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers • Types • ISI marking	06nos	08 nos	MR
		ABC/Co2	ABC-08	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor • Length of hose reel hose • Nozzle diameter	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
NA		NA	NA	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement • Upper Floor • Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450 lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000ltrs	10,000ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular / NBC Part 4, the FSC issued vide letter of even no 1274 dated 13.10.2014 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

M/1618

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

DO NWD - on m/Resh

Dy CFO/W2 - on leave

[Signature]
24/11/17

CFO/W2
24/11/17

F.T.P.L.

ADO/RN
CFO/W2
24/11/17

As approved, F.T. letter is pulip for your signature of.

1/11/17
27/18