

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2017/NDZ/ 1326

Dated: 6 /09/17

FIRE SAFETY CERTIFICATE

Certified that the New Oxford Public D-Block Preet Vihar, Delhi-91, owned/occupied by New Oxford Public, Comprised of ground plus two upper floors was granted NOC vide letter F6/MS/DFS/School/2014/NDZ/915 dated-23/07/14 (For ground floor only). The school building was inspected by the officer concerned of this department on 16/08/17 in the presence of Mr. Rohit Minocha (Manager) of the school and found that the school building is now comprised of ground plus two upper floor area have complied with the fire prevention and fire safety requirements in accordance with the NBC Part-IV and ground plus two floors of building is fit for occupancy class B "Educational Building" with effect from 6/8/17 for a period of **three** years, subject to conditions printed overleaf.

Issued on 6/8/17 at New Delhi by

4679
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

9/09/17

Copy to:-

- 1 The Director of Education,
EDMC,419,Udyog Sadan, Patparganj Industrial Area,Delhi-92.
2. The Manager,
New Oxford Public, D-Block Preet Vihar,Delhi-91.

3. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction.

• Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety certificate to the Director inform J[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : New Oxford Public D-Block Preet Vihar, Delhi-91.
2. Building is comprised of : Ground +2 upper floor
3. Type of Occupancy : Educational
4. Type of Case : Addition/Alteration
5. Details of Previous FSC : F6/MS/DFS/School/2014/NDZ/915 dt-23/07/14
(For ground floor only)
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 16/08/17
8. Name of the Inspecting Officers: : ADO R.K. Yadav
9. Name of the designation of Officer
from the building side : Mr.Rohit Kumar (Manager)
10. Year of Construction : 2008 & 2014
11. Applicant's letter No. : dated 24/07/17

S. No	Minimum Standards on fire safety requirements as per	Requirement	Provided at Site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2.	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 no.	2 no.	MR
	• Basement	N.A	N.A	N.A
	b. Width of Staircases			
	• Upper Floor	1.5 m	1.50 m & 1.25 m	MR
	• Basement	N.A	N.A	N.A
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	1 no.	1 no.	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1 m	1 m	MR
3.	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4.	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A
5.	Fire Extinguisher			
	Total numbers	6 no.	Provided	MR
	Types	CO ₂ & ABC	Provided	MR
	ISI marking	ISI marked	Provided	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A	N.A
8	MOEFA	N.A	Provided	MR
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	Basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	N.A	N.A	N.A
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	10,000 liters	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The NOC issued vide letter no. F6/MS/DFS/School/2014/NDZ/915 dt-23/07/14 (For ground floor only) renewal under the NBC Part-IV is recommended to grant Fire Safety Certificate.

R. K. Yadav

Signature of the Inspecting Officer

Name :- R. K. Yadav

Designation :- ADO (LN)

Dated:

Submitted for approval plan

DYCFO/NDZ

[Signature]

[Signature]
23/8/17

C.F.P.

what's floor area of 620 sq ft

DYCFO/NDZ

28/8

DYCFO/NDZ