

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/GH/2017/ 1354

Dated : 11/9/17

**FIRE SAFETY CERTIFICATE**

Certified that M/S **Al-Shahansha Guest House** located at **5190, Ballimaran, Chandni Chowk, Delhi-110006**. comprised of Ground floor (commercial use), 1<sup>st</sup> floor (06 guest rooms), 2<sup>nd</sup> floor (06 guest rooms) & 3<sup>rd</sup> floor (0 guest rooms) Total 18 guest rooms was granted FSC by this department vide letter No.F6/DFS/MS/GH/2014/NDZ/582 dated **08/05/2014**. The premise was re-inspected by the officer concerned of this department on **24/07/17** in the presence of Sh. Afaque Ahmad, manager of the guest house and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 for 18 guest rooms only as above** with effect from 11/9/17 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 11/9/17 at New Delhi by.

11/9/17  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

- 1 The Addl. C.P.(Lic.), Police Station, Defence colony, 1<sup>st</sup> floor, New Delhi.
2. The Owner, Al-Shahansha Guest House,5190, Ballimaran, Chandni Chowk, Delhi-110006.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed / unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to it expiry

M/8

INSPECTION REPORT

1. Name & address of the building:- Al-Shahansha Guest House, 5190, Ballimaran, Chandni Chowk, Delhi-110006.
2. Type of occupancy:- Residential Group A-1 ( Ground + 3 upper floors), GF- commercial use, 1<sup>st</sup> fl - 06 guest rooms, 2<sup>nd</sup> fl - 06 guest rooms, 3<sup>rd</sup> fl -06 guest rooms  
Total 18 guest rooms
3. Type of case:- Renewal
4. Details of previous FSC: - No. F6/DFS/MS/GH/2014/NDZ/582 dated 08/05/2014.
5. Fire safety directives No.- N/A
6. Date of inspection:- 24/07/17
7. Name of the inspecting officer:- A. D.O. Mehmood
8. Name & designation of officer  
From the building side:- Sh. Afaque Ahmad( manager)
9. Year of construction:- 2010
10. Applicant's letter No:- Nil dated - 06/07/2017

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement (Existing Fire Safety Measures)	Provided at site (PSS)	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	125 cms.	125 cms.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No	01 No.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	N/A	N/A

5.	Fire Extinguishers	06 Nos.	06 Nos.	MR
	1) Total numbers	06 Nos.	ABC & CO2	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	Required		
6.	First-Aid Hose Reel	01 No.	01 No.	MR
	1) Total number of each floor	01 No.	01 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			N/A
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System			N/A
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			N/A
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			N/A
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			N/A
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			MR
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR

*[Handwritten signature]*

M/10

		Required	Provided	MR
	d) Auto starting of pump			
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5000 ltrs.	9000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/GH/2014/NDZ/582 dated 08/05/2014, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended

*Mehmood*  
Mehmood

Assistant Divisional Officer

D.O. (Central)

*Arshad*  
878717

391/cfo/ndz  
11/11/17  
Dy CBO (NDZ)

*[Signature]*  
A/R

CFO

when & date

11/11/17