

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001
Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/Club/2017/SZ/ 1348

Dated: 08/09/17

FIRE SAFETY CERTIFICATE

Certified that **Friends Club Limited** located at **17 A, Friends Colony (West), New Delhi-110065**, comprised of **basement, ground plus two upper floors** was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Club/2014/SZ/953 dated 30.07.2014. The premises was re-inspected by the officer concerned of this department on 26.08.2017 in the presence of Mr. Pravin Kumar Mehta, General Manager of the club and found that the said club building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly Building**" as above with effect from the date of issuance of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/09/17 at New Delhi by


Vipin Kental
Chief Fire Officer

Copy to: -

1. The General Manager, Friends Club Limited, 17 A, Friends Colony (West), New Delhi-65
2. The Asstt. Commissioner (Excise), Office of the Commissioner of Excise, Govt. of NCTD, L & N Block, Vikas Bhawan, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	FRIENDS CLUB LIMITED, 17-A, FRIENDS COLONY (WEST), NEW DELHI-110065		
2	Type of Occupancy	Assembly Building "Group-D" (Club)		
3	Building Comprised of	Basements, Ground + 2 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Club/2013/SZ/953 dated 30.07.2014		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/94/1225 Dated 23-08-1994		
7	Date of Inspection	26-08-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Prayin Kumar Mehta (GM)		
10	Year of construction	1982		
11	Applicant letter No.	Nil dated 04/08/2017 (C-41)		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Required	6 mtr	MR
	2. Gate width	Required	4.5 mtr	MR
	3. Width of internal road	NA	NA	NA
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	1. Upper floors	Required	3 No's	MR
	2. Basement floor	Required	4 No's	MR
	b. Width of Staircase			
	1. Upper floors	Required	1.7, 1.53 & 1.15m (Gd to FF) 0.90 mtr (1 st floor to terrace)	MR (old case)
	2. Basement floor	Required	1.53, 1.15, 1.04 & 0.82m	MR (old case)
	c. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	Required	One	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	NA	NA	NA
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust Fans provided	MR
	• Upper floors	12 ACPH	Smoke venting provided in kitchen	MR
5.	Fire Extinguishers.			
	• Total numbers	35 No's	35 No's	MR
	• Types	ABC /Co2	ABC- 15, Co2-10, W.Co2-10	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	2 No's	2 No's	MR
	• Length of hose-reel hose.	30 mtr	30 mtr	MR
	• Nozzle Diameter	05 mm	05 mm	MR

7	Automatic Fire Detection and Alarming system.			
	1. Type of detectors	Required	Smoke.	MR
	2. Location of Main Panel	Required	Ground floor	MR
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	Required	Provided	MR
	5. Hooter's location	Required	Provided in entire bldg	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	1. Basement	Required	Provided	MR
	2. Upper floors	Required	Provided	MR
	3. Sprinkler above false ceiling	NA	Provided	NA
11.	Internal Hydrants.			
	1. Size of Riser/Down-comer	Required	100 mm	MR
	2. Number of Hydrant per floor	Required	Two	MR
	3. Hose box.	Required	Two	MR
12.	Yard Hydrants.			
	1. Total number of hydrants.	Required	6 No's	MR
	2. Hose box.	Required	6 No's	MR
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	2280 LPM	2280 LPM	MR
	➤ Head of main pump.	60 m	60 m	MR
	➤ Number of main pumps.	One	One	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	60 m	60 m	MR
	➤ Standby Pump output.	2280 LPM	2280 LPM	MR
	➤ Standby Pump head.	60 m	60 m	MR
	➤ Auto Starting / Manual Stopping.	Required	Required	MR
	➤ Pump house access	Required	Provided	MR
	b) Terrace Level			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	40 m	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	1,00,000 ltrs	1,00,000 ltrs	MR
	2. Draw-off connection.	Required	Provided	MR
	3. Fire Service Inlet.	Required	Provided	MR
	4. Access to tank.	Required	Provided	MR
	5. Overhead tank capacity.	20,000 Ltr.	20,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	Required	Provided	MR
	4. Fireman's switch.	Required	Provided	MR
	5. Lift signage.	Required	Provided	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

19.	Fire Control Room.		
	1. Detector System Panel.	NA	Panel NA
	2. Flow Switch Panel.	NA	NA NA
	3. PA system Panel.	NA	NA NA
	4. Battery backup	NA	Provided NA
	5. Building floor plan	NA	NA NA
20.	Special Fire Protection System for the Protection of special Risk, if any :	Required	Co2 type fire extinguishers provided near electrical panel MR

The Fire protection systems provided in the building were checked / operated and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/Club/2014/SZ/953 dated 30.07.2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

R.N. Singh
30/8/17

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

Renewal

Friends Club Limited, Friends Colony (West), New Delhi.

Div. Officer (SD)

Anilash
31/8/17

Sanjiv



CFO (S2)

m. sell

4/9