

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2017/SZ/ 1337

Dated: 8/9/17

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Boys Sr. Sec. School (A-Block) & Govt. Sarvodaya Kanya Vidyalaya (B-Block)**, Hastal Village, New Delhi-110059, comprised of two blocks namely A-Block & B-Block. Each block is having ground floor plus three upper floors owned/occupied by Govt. of NCT of Delhi was inspected by the officer concerned of this department on 16.8.2017 in the presence of Sh. Surinder Sethia (Estate Manager) & Sh. Saiful (Site Supervisor) and found that the Govt. Co- ed. Sarvodaya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....8.9.17..... at New Delhi.

W
5/9/17
(VIPIN KENTAL)
CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
Govt. Boys Sr. Sec. School, Hastal Village, New Delhi-110059.
2. The Principal,
Govt. Sarvodaya Kanya Vidyalaya, Hastal Village, New Delhi-110059
3. Director of Education,
Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Govt. Boys Sr. Sec. School (A-Block) & Govt. Sarvodaya Kanya Vidyalaya (B-Block), Hastsal Village, New Delhi-110059.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 16.8.2017
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers : Sh. Surinder Sethia (Estate Manager) & Sh. Saiful (Site Supervisor)
- From the building side
9. Year of Construction : 2016-2017
10. Applicant's letter No. : 20(4)/Edu.M.Divn (west)/PWD(GNCTD)/728 dated 10.7.2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	09 mtrs 05 mtrs N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	04 No.'s in each Block N/A	Provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	150 cms. N/A	175, 175, 160 & 150 cms in A-blk & 170, 170, 150 & 150 cms in B-blk N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door Size			
		Required	Two	M/R
		150 cms.	230 cms in A blk & 230 cms in B blk	M/R
		100 cms.	105 cms (Double door) in A-blk & 107 cms (Double door) in B blk	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 no.'s in each block ABC/CO ₂ type ISI marked	40 no.'s in each provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Three in each block 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R

7.	Automatic fire detection and alarming system	N/A	N/A	N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace level	450 LPM in each block	450 LPM (02 no.'s) in each block Provided	M/R
	➤ Discharge of pump	30 mtrs	Provided	M/R
	➤ Head of the pump	Required	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltrs in each block	16000 ltrs in each block provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			(Lift not in use)
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	M/R
	• Fireman's Grounding Switch	Required	Provided	M/R
	• Lift Signage	Required	Provided	M/R
		N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

M9

19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Sandeep
24/8/17

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

[Signature]
25/8/17

[Signature]
DCFO (S2)

604/D0/80
25/8/17

1171/CFOS2
29/8/17



[Signature]
25/8/17

CFD for

M-CELL

FT for

29/8

F.T. letter is put up for signature please

Sandeep
01/9/17

[Signature]

M-CELL

29/8/17