

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFs/MS/2017/School/52/1384

Dated: 19/09/17

**FIRE SAFETY CERTIFICATE**

Certified that M/s Ganesh Shankar Vidyarathi Sarvodaya Bal Vidyalaya No.1, Sarojini Nagar, New Delhi-110023, comprised of ground plus one upper floor only (two blocks), owned/occupied by Government on NCT of Delhi, Education Department, have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officer concerned of this department on 11.09.2017 in the presence of Mr. K.S. Joon, Principal of the school and found that the building is fit for occupancy class B 'Educational Building' with effect from ...19/09/...2017 for a period of three years, subject to conditions printed below.

Issued on...19/09/...2017 at New Delhi by

*Vipin Kental*  
(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

To:- 1. The Principal, Ganesh Shankar Vidyarathi Sarvodaya Bal Vidyalaya No.1, Saroini Nagar,  
New Delhi-110023. *o/c*

2. The Director of Education, Old Secretariat, Delhi-110052.

**Conditions for the validity of fire safety certificate are as under:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.



**INSPECTION REPORT**

1	Name & address of the building	M/s Ganesh Shankar Vidyarathi Sarvodaya Bal Vidyalaya No.1, Saroini Nagar, New Delhi-110023.
2	Type of Occupancy	Educational Building "B"
3	Type of case	New Case
4	Details of previous NOC	Nil.
5	Fire safety directives letter No	F.16/Estate/CC/Fire safety/2011/3298 to 3398, Dated-01.03.11.
6	Date of inspection	11.09.2017.
7	Name of the inspecting Officers	A.D.O. Vedpal.
8	Name and designation of officers from the building side	Mr. K.S Joon, Principal of the school.
9	Building Comprised of	Ground plus one upper floor only (Two Blocks)
9	Year of construction	Very old building Not Known
10	Applicant's letter No.	No. GSV/SBV No1/NOC/2017-18/123-125, Dated 1.8.17.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Circular of Director of Education dt 01.03.11	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	Accessible	9m	MR
	2) Gate width	Required	4.5m Provided	MR
	3) Width of internal road	N/A		N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	02nos. In each block	02nos. In each block	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5m/75cm	one block=1.5 & 1.4m 2nd block=1.2m & 1.80m	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door.	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	one no in each block	N/A
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1 Mtr	Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers.	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	N/A	N/A
	Upper Floors	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	Total numbers	20nos	38nos.	MR
	Types	ABC & WCO2	ABC, CO2 & Water CO2	MR
	ISI marking	ISI Mark	ISI Mark	MR



6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	Provided	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A



N/3

19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

**20 Special Fire Protection systems for protection of special risks, if any: N/A**

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety systems required under Director of Education circular No.3298-3398 dated 01.03.2011. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Accordingly DFA is put up for your approval and signature please.

*[Handwritten Signature]* 11/9/17

Signature of the inspecting officer

Name: Vedpal

Designation : ADO

~~D.O. (S.D.)~~  
*[Handwritten Signature]*  
 12/9/17

dy. CP (S.D.)

*[Handwritten Signature]*  
 12/9



1224/CPJL  
 1419/19.9

CPo (S.D.)

m-scull

FT 101