

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI****HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F6/DFS/MS/WZ/2017/ 1389

Dated: 20/09/2017

**FIRE SAFETY CERTIFICATE**

Certified that the Kamal Pharmacy (Ayurvedic) pvt. Ltd located at 14, Industrial Area, Shivaji Marg, (Najafgarh Road), New Delhi-110015, comprised of Ground Floor, Mezzanine and First Floor was granted NOC / FSC by this department vide letter F-6/DFS/MS/2012/2799 dated 27/07/2012. The premises was re-inspected by the officer concerned of this department on 04/09/2009 in the presence of Mr. Rochak Arora and observed that Fire prevention and Fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with requirement under rule 33 of the Delhi Fire Service Rule 2010 and that the building / premises is fit for occupancy class **Industrial** Group-G (G-1) with effect from 20.09.17...for a period of 3 (three) years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010 Issued on.....20/09/17.....at New Delhi.

(ATUL GARG)  
CHIEF FIRE OFFICER.

Copy to:

1. Authorized Signatory, Kamal Pharmacy (Ayurvedic) pvt. Ltd, 14, Industrial Area, Shivaji Marg, (Najafgarh Road), New Delhi-110015.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment's shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building : **Kamal Pharmacy (Ayurvedic) pvt. Ltd** located at 14, Industrial Area, Shivaji Marg, (Najafgarh Road), New Delhi-110015.
2. Type of Occupancy : Class-G (G1) Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2012/2799 dated 27-07-2012
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 04-09-2017
7. Name of the Inspecting Officers : A.K. JAISWAL ADO (JWP)
8. Name and designation of officers  
From the building side : Mr. Rochak Arora
9. Year of Construction : 2005-06
10. Applicant's letter No. : KPPL/35/17 dated 09-06-17

Ground Floor, Mezzanine  
Floor & 1<sup>st</sup> Floor

**Total Plot Area-275 m<sup>2</sup>**

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6 mtr	12 mtr	M.R.
		4.5 mtr	5 mtr	M.R.
		N.R.	N.R.	N.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	1	2	M.R.
	• Upper Floors	NR	NR	M.R.
	• Basement	N.A	N.A	N.A
	b. Width of staircases			
	• Upper Floors	1.50 mtr	A) Ground to Mezzanine Floor-1x1.10 mtr & 1x 0.70 mtr. B) Ground Floor to 2 <sup>nd</sup> Floor-1x1.30 mtr	M.R. (Being Old Case)
	• Basement	N.A	N.A	N.A
	c. Protection of exits	N.R	N.R	N.R
	• Fire check door			
	• Pressurization	N.R	N.R	N.R.
	d. No. of continuous staircases to terrace	1	1	MR
	e. Width of Corridor	Halls only	Halls only	M.R.
	f. Door size	1 mtr	1 mtr	M.R.
3.	<b>Compartmentation.</b>			
	• Fire check door	N.R	N.R	N.R.
	• Sealing of electrical shafts	N.R	N.R	N.R.
	• Fire Rating of shaft door	N.R	N.R	N.R.
	• Water Curtain	N.R	N.R	N.R.
	• Fire Dampers	N.R	N.R	N.R.



	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	required	Exhaust fans are provided	M.R
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	10	13	M.R
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC type	provided	M.R
	<ul style="list-style-type: none"> <li>ISI marking</li> </ul>	ISI marked required	provided	M.R
<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	1	1	M.R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	30 mtr	M.R
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	5 mm	M.R
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N.R	N.R	N.A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N.R	N.R	N.A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N.R	N.R	N.A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N.R	N.R	N.A
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	N.R	N.R	N.A
<b>8.</b>	<b>MOEFA</b>	N.R	N.R.	M.R.
<b>9.</b>	<b>Public Address System</b>	N.R.	N.R.	N.A
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N.R.	N.R.	N.R.
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150 mm	150 mm	M.R.
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	1	1	M.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	1	1	M.R.
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N.R.	N.R.	Not applicable.

	<b>Ground Level</b>			
	➤ Discharge of main pump	N.R.	N.R.	N.R
	➤ Head of Main pump	N.R.	N.R.	N.R
	➤ Number of main pumps	N.R.	N.R.	N.R
	➤ Jockey Pump out put	N.R.	N.R.	N.R
	➤ Jockey pump head	N.R.	N.R.	N.R
	➤ Standby pump out put	N.R.	N.R.	N.R
	➤ Standby pump Head	N.R.	N.R.	N.R
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R
	➤ Pump Hose Access	N.R.	N.R.	N.R
	<b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	450 LPM	M.R
	➤ Head of the pump	40 mtr	40 mtr	M.R
	➤ Power supply	Required	provided	M.R
	➤ Auto Starting of pump	Manual	Provided	M.R
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	N.R.	N.R.	N.R
	➤ Draw -off connection	N.R.	N.R.	N.R
	➤ Fire service inlet	N.R.	N.R.	N.R
	➤ Access to tank	N.R.	N.R.	N.R
	➤ Overhead Tank Capacity	10,000 ltr	12,000 ltr	M.R
<b>15</b>	<b>Exit Signage.</b>	N.R.	N.R.	N.A
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.A.	N.R.	N.R.
	• Pressurization of Lift lobby	N.A.	N.R.	N.R.
	• Communication In lift Car	N.A.	N.R.	N.R.
	• Fireman's Grounding Switch	N.A.	N.R.	N.R.
	• Lift Signage	N.A.	N.R.	N.R.
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R



18.	Refuge Area	N.R.	N.R.	N.A.
	➤ Total Area	N.R.	N.R.	N.A.
	➤ Location	N.R.	N.R.	N.A.
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	Not applicable
	➤ Flow Switch Panel	N.R.	N.R.	Not applicable
	➤ PA system Panel	N.R.	N.R.	Not applicable.
	➤ Batter backup	N.R.	N.R.	Not applicable.
	➤ Building Floor plans	N.R.	N.R.	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F-6/DFS/MS/2012/2799 dated 27-07-2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.P. (C)

*[Signature]*  
11/8/17

~~D.Y. CEO (22)~~

*[Signature]*  
14/9/17

CFD  
15/9/17  
F.P.

*[Signature]*  
5/9/17

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

F.P. is added for sign. pl.  
A.D.O. *[Signature]* 14/9/17