

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No.F6/DFS/MS/Club/SZ/2017 /1373

Dated: 18/09/17

**FIRE SAFETY CERTIFICATE**

Certified that M/s Taj Sats Air Catering Ltd, located at IGI Airport Complex, New Delhi-110037, comprised of basement, ground plus one upper floor only, owned/occupied by Taj Sats Air Catering Ltd, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2014/SZ/1076, dated 28-08-2014. The premises was re-inspected by the officer concerned of this department on 11-09-2017 in the presence of Sh. Umakant Shrimali, Chief Engineer and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class G "Industrial" (Flight Kitchen) with effect from ...18/09/2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on...18/09/2017.....2017 at New Delhi by

  
(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy to:- 1. The Dy. Health Officer, Health Department, SDMC, Najafgarh, New Delhi. o/c  
2. Chief Engineer, M/s Taj Sats Air Catering Ltd, located at IGI Airport Complex, New Delhi. h

**Conditions for the validity of fire safety certificate are as under:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.



1. Name & address of the building : M/S Raj Sats Air Catering Ltd, located at ISI Airport Complex, New Delhi-110037.

2. Building is comprised of : Basement, ground plus one upper floor only.

3. Type of Occupancy : Class "G" (Industrial Occupancy i.e. Flight Kitchen).

4. Type of Case : Renewal.

5. Details of Previous NOC : No.F6/DFS/MS/2014/SZ/1076, dated 28.08.2014.

6. Fire Safety direction letter No : Nil.

7. Date of Inspection : 11.09.2017.

8. Name of the Inspecting Officers: : Vedpal (ADO)

9. Name and designation of Officer from the building side : Sh. Umakant Shrimali (Chief Engineer).

10. Year of Construction : 1983.

11. Applicant's letter No : No. Nil, Dated 31.08.17.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements as per old NOC dt 22.08.2014	Provided at Site	Remarks
1	Access to building			
	Road width	6m	9m	MR
	Gate width	4.5m	5m	MR
	Width of internal road	Required	Provided	MR
2	Number, Width, Type and Arrangement of Exits.			
a.	Number of Staircases	Required	Provided	MR
	Upper Floor	02nos.	02nos.	MR
	Basement	01no.+1ramp	01no.+1ramp	MR(old case)
	B. Width of Staircases	Required	Provided	MR
	Upper Floor	Required	1.18m(each)	MR(old case)
	Basement	Required	1.19m & ramp=3.20m	MR(old case)
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01no.	01no.	MR
g. Width of Corridor	N.A.	N.A.	N.A.	
h. Door Size	N.A.	N.A.	N.A.	
3	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fans Provided	MR
	Upper floor	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguisher			
	Total numbers	80 nos.	120nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> , WCO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on each floor	Required	BF=01no.GF=10nos & FF=07nos.	MR
	Length of hose reel hose	30m.	30m Provided	MR
	Nozzle diameter	5mm	5mm Provided	MR
7	Automatic fire detection and alarming system.			
	Fire detectors	Required	Smoke & Heat	MR



9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	150mm	150mm	MR
	Number of hydrants per floor.	Required	BF=01no.GF=10nos & FF=07nos.	MR
	Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	Required	04nos.	MR
	Hose Box	Required	04nos.	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	1830LPM	1830LPM	MR
	➤ Head of Main Pump	70m	70m	MR
	➤ Number of main pumps	02nos.	02nos.	MR
	➤ Jockey pump out put	180LPM	180LPM	MR
	➤ Jockey pump head	70m	70m	MR
	➤ Standby pump out put	1830LPM	1830LPM	MR
	➤ Standby pump Head	70m	70m	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	90000Liters.	90,000Liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	10000Liters.	10000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	Required	Provided	MR
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	Required	CO2 & ABC Fire Extinguishers	MR



M/S Taj Sats Air Catering Ud 16/1 Airport Complex.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/2014/SZ/1076, dated 28.08.2014 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration and necessary approval please.

*[Handwritten Signature]*  
11/9/17

Signature of the Inspecting Officer

Name : Vedpal

Designation: Assistant Divisional Officer

~~D.O. (S.D)~~

*[Handwritten Signature]*  
12/9/17

*[Handwritten Signature]*  
12/9/17

*[Handwritten Signature]*



CFO/27

Miscell

FT 10-

12/9

FT letter is put up for sign please  
*[Handwritten Signature]*