

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No.F6/DFS/MS/2017/SZ/ misc) 1414

Dated: 26/09/17

FIRE SAFETY CERTIFICATE

Certified that the M/s Fun "N" Food Village, Polo Amusement Park Ltd, located at Village Kapashera, New Delhi-37, comprised of ground floor only owned/occupied by M/s Polo Amusement Park Ltd was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2014/1117, dated 03-09-2014. The premises was re-inspected by the officer concerned of this department on 20-09-2017 in the presence of Sh. Mahender Sharma (Manager) and found that the said amusement park building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for Occupancy Class-D "Assembly" with effect from ...26/09/2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on....26/09/2017 at New Delhi by



(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

- Copy to:- 1. The Joint Commissioner of Police, Licensing Unit, PS Defence Colony, New Delhi-110043 w.r.t. letter No.1820-24/Addl.C.P./Lic(Amst.), dated 3.08.17.
2. Authorized Signatory, M/s Fun "N" Food Village, Polo Amusement Park Ltd, located at Village Kapashera, New Delhi-37.



Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

1. Name & address of the building : M/s Fun "N" Food Village, Polo Amusement Park Ltd. located at Kapashera, New Delhi-110037.
2. Building is comprised of : Ground floor only.
3. Type of Occupancy : Assembly.
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/2011/2121, Dated 30.08.2011.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 20.09.17.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Mahender Sharma (Manager)
10. Year of Construction : 1992.
11. Applicant's letter No : Nil, dated 28.08.17.

S.No	Minimum Standards on fire prevention and fire safety U/R-33	Requirements/Existing Fire Protection System	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	Required	12 m	MR
	Gate width	5m	5m(Two)	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
3	a. Number of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	N.A.	N.A.	N.A.
4	Compartmentation			
5	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
5	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.
5.	Fire Extinguisher			
6	Total numbers	25nos.	25nos.	MR
	types	CO ₂ & ABC	ABC Type	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
7	Total numbers of each floor	Required	07nos.	MR
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5mm	5mm	MR.
7	Automatic fire detection and alarming system.			
8	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.

8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	Required	02Nos	MR
	Hose Box	Required	02Nos.	MR
13	Pumping Arrangements.			
	➤ Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	450LPM	450LPM	MR
	➤ Head of Main Pump	40m	40m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	225LPM	225LPM	MR
	➤ Jockey pump head	40m	40m	MR
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	100000 liters	100000 liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	DG Set 150 KVA	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.

N/32

M/s Fun "N" Food Village, Polo Amusement Park Ltd. Kapashera, New Delhi-110037.

20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.
----	--	------	------	------

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/2014/1117, dated 03.09.2014 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended. It is also submitted that shortcomings issued vide letter dated 08.08.2014 have been complied at serial numbers 6, 8, 12, 13 & 15.

Reply letter in shape of DFA is put up for your kind consideration and necessary approval please.

[Handwritten Signature]
21/9/17

Signature of the Inspecting Officer
Name Vedpal
Designation ADO(S.J.)

D.O.(South)

[Handwritten Signature]
21/9/17

[Handwritten Signature]

[Handwritten Signature]
21/9

FTM.

CFO (S/J) M'scell 22/9

FT letter is put up for sign/phrase

[Handwritten Signature]
26/9
AOC(S)

1228/cfo/2
26/9.

CFO (S/J) M'scell 26/9

